Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2024/91480 - Asda Stores, Bradford Road, Fixby, Huddersfield, HD2 2LQ		
Replacement of existing plant condenser unit for new		
Responding Date: **10 July 2024**	**Responding Officer:** **Mohammed Nasim**	**Responding Ref:** **WK202419406**
Comments The submitted drawing no. PL_05 from Whittam Cox Architects dated May 2024 shows the proposed location of the installation along with the model no. JEHS-0300-B2-L-3 with a sound pressure level of 33dB @ 10m. Based upon the distance to the nearest noise sensitive receptors and the location between the store and the retaining wall, we have no objection to the proposed installation.		