

DCAdmin

From: Farhad Khatibi
Sent: 27 June 2024 14:49
To: Planning ContactCentre
Subject: RE: Attached letter from Kirklees Council regarding application number 2024/91635 at location former, Stile Common Infant & Nursery School, Plane Street, Newsome, Huddersfield, HD4 6DF

Hi Nick

I would like to advise that condition 13 (retaining structures) can not be discharged pending the formal technical approval for the proposed modifications to the existing retaining wall and design of new retaining walls abutting the existing/ proposed highway via submission of AIPs.

Regards

Farhad Khatibi

Bridges & Structures Manager
Structures Section
Highways and Streetscene
Kirklees Council

Highways and Streetscene | Highways Structures | Civic Centre 1 | High Street | Huddersfield | HD1 2NF

 **External:** 01484 221000 **Internal:** 74199

Mobile: None

 **Email:** farhad.khatibi@kirklees.gov.uk