

Consultation Response from KC, Lead Local Flood Authority
2024/91918 East Bierley Playing Fields, Hunsworth Lane, East Bierley, BD4 6PU
Discharge of details reserved by conditions 3 (C(E)MP), 4 (drainage), 21 (3G/synthetic pitch), 23 (drainage) and 25 (crime and anti-social behaviour) of previous permission 2021/90357 for works to existing sports facilities including erection of a clubhouse, additional changing facilities building, boundary treatments, storage facilities and floodlighting, works to existing pitches, and creation of new hybrid and 3G/synthetic pitches, multi sport training area and car park
Date Responded: 10/10/2024. Responding Officer: Martin Stephenson Responding Ref: 1
 <u>Previous response by the LLFA</u> Dated 25/03/2021 for application 2021/90357 <u>Discharge of Drainage Conditions</u> <ul style="list-style-type: none">• No. 4 (Temporary Drainage)• No. 23 (Surface Water Drainage) <u>Documents reviewed by the LLFA:</u> SEA Consulting: <ul style="list-style-type: none">• 00176/E02, Proposed Drainage Layout - Sheet 1 of 2, Rev – dated 25/05/2024• 00176/E03, Proposed Drainage Layout - Sheet 2 of 2, Rev – dated 25/05/2024• R-00176-001-SDS, Surface Water Strategy, Rev 0 dated 09/06/2024 <u>Drainage Summary:</u> <u>Condition 4</u> No information regarding the temporary drainage proposals have been submitted, Therefore Condition 4 cannot be discharged. <u>Condition 23</u> The LLFA confirms acceptance of the submitted Drainage Layout drawing and Surface Water Strategy document including the proposal to restrict the off-site surface water discharge rate to 4.7 l/s via a hydrobrake with an outlet diameter of 99mm (as shown on the drawings at MH S13) discharging into a local ditch (downstream of MH S23). Therefore Condition 23 can be discharged