

Consultation Response from: KC Environmental Health (Pollution & Noise Control)
2024/91932 Land adj 33 Brooke Street, Cleckheaton, BD19 3RY
Erection of one dwelling and associated works
Responding Date:
27th January 2025
Responding Officer:
SR
Responding Ref:
WK202501596
Comments

We have reviewed the application and supporting information, we offer the following comments. The application appears to concern the erection of a single detached dwelling on a strip of land in between two existing dwellings.

Noise

There is an existing commercial property to the rear of the proposed dwelling which appears on mapping to be serviced by several transit type vehicles. In order to protect the amenity of future residents from noise associated with the commercial operation, we recommend a condition for a noise assessment to be undertaken and any necessary mitigation applied.

Contaminated Land

This site of the proposed development is not situated on land identified as potentially contaminated. Whilst we have no objection to the application, groundworks will be necessary and a watching brief should be observed in relation to unexpected contamination and we therefore recommend a condition.

Construction Related Noise

In order to protect the amenity of neighbouring residents we recommend a condition to ensure construction noise associated with the proposal does not cause loss of amenity.

Electric Vehicle Charging Points

We would remind the applicant that approval under the Building Regulations may be required for EVCP's, and the applicant should contact their Building Control Provider for further information in relation to Approved Document S.

Recommended Conditions
NC9 Noise Assessment Report and Mitigation Scheme - Condition

Before construction work commences a report specifying the measures to be taken to protect the development from noise from all significant noise sources that are likely to affect the proposed development including road traffic and commercial premises shall be submitted to and approved in writing by the Local Planning Authority.

The report shall:

- a) Determine the existing noise climate
- b) Predict the noise climate in living rooms and gardens (daytime), bedrooms (night-time) and other habitable rooms of the development
- c) Detail the proposed attenuation/design necessary to protect the amenity of the occupants of the new residences (including ventilation if required).

The development shall not be occupied until all works specified in the approved report have been carried out in full and such works shall be thereafter retained.

Reason: To protect the amenity of occupiers of the proposed development from noise or disturbance from nearby noise generating premises to accord with the aims of Policies LP24 and LP52 of the Kirklees Local Plan and Chapters 12 and 15 of the National Planning Policy Framework.

NF4 Competent Person - Footnote

All noise assessments should be carried out by a competent person. The applicant may wish to contact the Association of Noise Consultants <http://www.association-of-noise-consultants.co.uk/> (020 8253 4518) or the Institute of Acoustics <http://www.ioa.org.uk> (0300 999 9675) for a list of members.

CLC6 Reporting of Unexpected Contamination – Condition

If contamination, the presence of coal and/or evidence of coal workings not previously identified by the developer prior to the grant of this planning permission is encountered during the development, all works in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Works in the affected area shall not recommence until either (a) a Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority or (b) the Local Planning Authority has confirmed in writing that remediation measures are not required. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures. Thereafter remediation of the site shall be carried out and completed in accordance with the approved Remediation Strategy.

Following completion of any measures identified in the approved Remediation Strategy a Verification Report shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as that part of the site has been remediated in accordance with the approved Remediation Strategy and a Verification Report in respect of those works has been approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 189 and 190 of the National Planning Policy Framework.

CLC7 Contaminated land - Footnote

All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework 2021. Reports must be prepared in accordance with the following guidance:

- *Land Contamination Risk Management (LCRM)*
- *BS 10175:2011+ A2:2017 Investigation of Potentially Contaminated Sites. Code of Practice*
- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020* by the Yorkshire and Lincolnshire Pollution Advisory Group.

The conditions relate to Planning Control only. Approval under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further

information. Any other necessary consent must be obtained from the appropriate authority. If the applicant commences work without discharging conditions, they will be at risk of enforcement action and invalidating the permission if the planning condition is a pre commencement condition.

CSC1 Construction Site Working Times - Condition

No construction related noise shall be audible beyond the site boundary outside the hours of: 07.30 to 18.30 hours Mondays to Fridays

08.00 to 13.00 hours, Saturdays

With no construction related noise audible beyond the site boundary on Sundays or Public Holidays.

Reason: To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and LP52 of the Local Plan

CSF1 Construction Sites working times – Footnote

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.