



YorkshireWater

Mathias Franklin
Head of Planning Services
Kirklees Metropolitan District Council
P.O. Box B93
Civic Centre
Huddersfield
HD1 2JR

Yorkshire Water Services
Developer Services
Sewerage Technical Team
PO BOX 52
Bradford
BD3 7AY

Tel: 0345 120 8482

Email:
planningconsultation@yorkshirewater.co.uk

Your Ref: 2024/91963

Our Ref: A004614

18th October 2024

Dear Sir/Madam,

Bradley Mills Road, between Kilner Bank and Brownroyd Avenue Dalton – Highway improvements works comprising carriageway and footway widening along with new kerb line and pedestrian barrier on north side of the highway between Kilner Bank and Brown Royd Avenue; new planting and hedgerow on northern land boundary to replace existing chain link fence

Thank you for consulting Yorkshire Water regarding the above proposed development. We have the following comments:

Water Supply

There is a 15 inch and 4 inch cast iron water mains in in the highway. Work in the highway and associated protection to this asset is covered by NRASWA regulations. (additional mains protection documents are attached)

Waste Water

There is a 225mm combined water sewer in the highway. Work in the highway and associated protection to this asset is covered by NRASWA regulations.

Yours faithfully

Reuben Thornton
Developer Services Team

