

Sent: 16 May 2025 14:49

Subject: RE: Attached letter from Kirklees Council regarding application number 2024/91971 at location Land at, Green Acres Close, Emley, Huddersfield, HD8 9RA

I would like to advise that condition 11 (drainage) cannot be discharged pending the necessary rectification of the notes in the submitted drawings, as advised, together with the submission of a satisfactory "Design & Check Certificate" for oversize manholes.

I understand that the drainage works may have been completed in advance of acquiring a technical approval for these structures.

Regards

Farhad Khatibi

Bridges & Structures Manager
Structures Section
Highways and Streetscene
Kirklees Council

Highways and Streetscene | Highways Structures | Civic Centre 1 | High Street | Huddersfield | HD1 2NF

☎ **External:** 01484 221000 **Internal:** 74199

Mobile: None

✉ **Email:** farhad.khatibi@kirklees.gov.uk

