

**Consultation Response from KC,  
Lead Local Flood Authority****2024/92168 Land south of, Leak Hall Barn, off Leak Hall Lane, Denby Dale, Huddersfield, HD8  
8QU****Outline application for erection of residential development of 13 dwellings****Date Responded: 11/09/2024****Responding Officer: Martin Stephenson****Responding Ref: 1****Documents reviewed by the LLFA:**

EWE Associates:

- Ref: 2024/3100, Drainage Assessment, Rev 0 dated 29/06/2024.

**Drainage Summary:**

The LLFA accepts that infiltration is not feasible as noted in the Drainage Assessment and concurs with the proposal for the surface water allowable discharge rate to be **3.5 l/s** and the discharge point is the public sewer in Leak Hall Crescent (subject to Yorkshire Water acceptance).

**Advisory Note:**

It is noted that the proposal for attenuation storage would be twin 900mm dia pipes within the adoptable road – note that KC Highways may not adopt roads with pipes of 900mm diameter or above.

**Kirklees Flood Management & Drainage as Lead Local Flood Authority SUPPORTS this application SUBJECT to the comments above and the recommended conditions set out below.**

**DR01 Drainage Details**

Development shall not commence until a detailed design scheme detailing foul, surface water and land drainage, including agreed discharge rates with the LLFA indirectly or directly to watercourse, attenuation for the critical 1 in 100 (plus an allowance for climate change) rainfall event, attenuation construction details /design, plans and longitudinal sections, hydraulic calculations and phasing of drainage provision has been submitted to and approved in writing by the Local Planning Authority. The scheme shall include a risk assessment and method statement, in accordance with CDM Regulations 2015, for access to and into the attenuation structure, and the scheme shall include a maintenance and management plan for surface water infrastructure. No part of the development shall be occupied until such approved drainage scheme has been provided on the site to serve the development or each agreed phasing of the development and retained thereafter.

**DR07 Overland Flow Routing**

The development shall not commence until an assessment of the effects of 1 in 100 year storm events, with an additional allowance for climate change, blockage scenarios and exceedance events on drainage infrastructure and surface water run-off pre and post development between the development and the surrounding area (both upstream and downstream of the development), has been submitted to and approved in writing by the Local Planning Authority. No part of the development shall be brought into use (dwellings shall not be occupied) until the works comprising the approved scheme have been completed and such approved scheme shall be retained thereafter.

**DR10 Construction Phase Surface Water Flood Risk and Pollution prevention plan.**

Development shall not commence until a scheme, detailing temporary surface water drainage for the construction phase (after soil and vegetation/site strip) has been submitted to and approved in writing by the Local Planning Authority. The scheme shall detail:

- phasing of the development and phasing of temporary drainage provision.
- include methods of preventing silt, debris and contaminants entering existing drainage systems

and watercourses and how flooding of adjacent land is prevented.

- the strategy shall include a plan showing the location of the attenuation storage and supporting calculations, which shall be based on the critical 1 in 2-year storm. It should be assumed that once the site has been stripped that the percentage run-off will be 100 %. The maximum allowable off-site discharge rate shall not exceed 2.5 litres per second per ha, unless otherwise agreed with the LLFA.

The temporary works shall be implemented in accordance with the approved scheme and phasing. No phase of the development shall be commenced until the temporary works approved for that phase have been completed. The approved temporary drainage scheme shall be retained until the approved permanent surface water drainage system is in place and functioning in accordance with written notification to the Local Planning Authority.