

**Consultation Response from KC,
Lead Local Flood Authority**

2024/92281 Land adj, 17, Whitehall Road West, Birkenshaw, BD11 2LS

Erection of 23 dwellings

Date Responded: 22nd October 2024

Responding Officer: Paul Farndale

Responding Ref:

There appears to be confusion regarding the submissions since our last commentary. Two different layouts are submitted with the flood routing plan and the drainage layout.

In addition, flooding is shown on the simulation which is unacceptable. We also need the inputs for drainage areas associated with the simulation. This must clearly identify the external road's contributions to the attenuation design