

**Consultation Response from KC,
Lead Local Flood Authority**

2024/92341 3, Lockwood Scar, Lockwood, Huddersfield, HD4 6BL

Alterations to dwelling to form 2 flats and 3 bed House in Multiple Occupation (Listed Building)

Date Responded: 29th September 2024

Responding Officer: Paul Farndale

Responding Ref:

Kirklees Flood Management & Drainage OBJECTS to this application. Self contained basement flats should only be considered in flood zone 1.