





7913 Trinity One, Huddersfield - Planning Conditions: Item 19 - Drainage Connection

CM Chris Murphy
To: **Kyle Furness**

Reply Reply All Forward
Wed 31/01/2024 11:53

Dear Kyle,

Ref: Planning Conditions Item 19 – Suspected Watercourse in the SE corner of the site:

It is noted that historic site records and utility plans suggested the possible existence of a supposed 'watercourse' appearing to connect from the former MIs 16 & 17 in the SE corner of the site to the main public sewer in the highway.

However, based on the investigations so far undertaken on site by Stainforth Construction, WML are generally satisfied that the matter of a possible watercourse thought to exist in the SE corner of the site has been explored and the suspected 'watercourse' found to be an existing SW outfall drain connection to the main existing sewer system located beneath the highway to the SE.

Based on site information provided by Stainforth Construction, WML would confirm that as part of the enabling works (so as to accommodate planned future development on the site), the final on site downstream MI connection on this run has been re-constructed as a new chamber with a connection spur to receive the new on site SW drainage connection, and the new chamber position and levels coordinated with the designer of the new on site drainage.

As discussed in recent correspondence it would be useful if all of the associated site records, relevant progress photographs, cctv reports, etc., could be compiled for submission along with this statement in order to assist with the Planning Officer's review.

We trust that this information is sufficient for your requirements.

Regards

Chris Murphy
BEng (Hons) CEng MStructE

WML Consulting Ltd
Civil, Structural & Geotechnical Engineers
Third Floor South | Metropolitan House | Station Road | Cheadle Hulme | Cheshire | SK8 7AZ

Tel: **01457 861111**

WE'VE MOVED!
Third Floor South, Metropolitan House,
Station Road, Cheadle Hulme, SK8 7AZ
Visit our website at:
www.wmlconsulting.com

This e-mail, and any file transmitted with it, contains information which is confidential and may also be legally privileged. It is intended solely for the exclusive use of the addressee. If you are not the intended addressee, please take notice that any distribution, copying, use or disclosure of its contents to any other person is prohibited. If you have received it in error, please advise the sender immediately and delete this e-mail and any copies of it from your system.

Although this email and any attachments are believed to be free of any virus, or any other defect which might affect any computer or IT system, it is the responsibility of the recipient to ensure that they are virus free, and no responsibility is accepted by WML Consulting Ltd for any loss or damage arising from receipt or use.

The Institution of **Structural Engineers** **CHAS** **Constructionline** **INVESTORS IN PEOPLE**
We invest in people. Standard

Please consider the environment before printing this e-mail