Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2024/92430 - Adj, 6, Springfield Avenue, Clayton West, Huddersfield, HD8 9HJ		
Outline application for erection of detached dwelling with parking		
Date Responded: **23rd October 2024**	**Responding Officer:** **NH**	**Responding Ref:** **WK/202433933**

Noise
The proposed development is in the immediate vicinity of the sports facility. Therefore, the proposals introduce sensitive noise receptors close to a potential noise source. Consequently, we recommend conditions for a noise assessment report. Conditions are also necessary to restrict the construction hours to safeguard the amenities of the occupiers of nearby properties.

Contaminated Land
Where groundworks are proposed, we would recommend the following unexpected contamination condition and footnote be applied.

Electric Vehicle Charging Points – Advisory
We note that parking is proposed at this development. We would encourage any electric vehicle charging points installed as part of this development to meet the requirements of the *Air Quality & Emissions Technical Planning Guidance* from the West Yorkshire Low Emissions Strategy Group. The applicant should note the information in the recommended Electric Vehicle Charging Points Footnote.

Recommended Conditions
NC9 Noise Assessment Report and Mitigation Scheme - Condition
Before any enabling or construction work commences, a report specifying the measures to be taken to protect the development from noise from all significant noise sources that are likely to affect the proposed development including any commercial premises shall be submitted to and approved in writing by the Local Planning Authority.
The report shall:

a. Determine the existing noise climate
b. Predict the noise climate in living rooms and gardens (daytime), bedrooms (night-time) and other habitable rooms of the development
c. Detail the proposed attenuation/design necessary to protect the amenity of the occupants of the new residences (including ventilation if required).

The development shall not be occupied until all works specified in the approved report have been carried out in full and such works shall be thereafter retained.
Reason: To protect the amenity of occupiers of the proposed development from noise or disturbance from nearby noise generating premises to accord with the aims of Policies LP24 and LP52 of the Kirklees Local Plan and Chapters 12 and 15 of the National Planning Policy Framework.

NF4 Competent Person - Footnote
All noise assessments should be carried out by a competent person. The applicant may wish to contact the Association of Noise Consultants http://www.association-of-noise-

consultants.co.uk/ (020 8253 4518) or the Institute of Acoustics http://www.ioa.org.uk (0300 999 9675) for a list of members.

CSC1 Construction Site Working Times - Condition
No construction related noise shall be audible beyond the site boundary outside the hours of:

- 07.30 to 18.30 hours Mondays to Fridays
- 08.00 to 13.00 hours Saturdays

With no construction related noise audible beyond the site boundary on Sundays or Bank/Public Holidays.
Reason: To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and LP52 of the Local Plan

CSF1 Construction Sites working times – Footnote
Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited

CLC6 Reporting of Unexpected Contamination - Condition
If contamination, or the presence of coal not previously identified by the developer prior to the grant of this planning permission is encountered during the development, all works in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Works in the affected area shall not recommence until either (a) a Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority or (b) the Local Planning Authority has confirmed in writing that remediation measures are not required. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures. Thereafter remediation of the site shall be carried out and completed in accordance with the approved Remediation Strategy. Following completion of any measures identified in the approved Remediation Strategy a Verification Report shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as that part of the site has been remediated in accordance with the approved Remediation Strategy and a Verification Report in respect of those works has been approved in writing by the Local Planning Authority.
Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 189 and 190 of the National Planning Policy Framework.

CLC7 Contaminated land - Footnote
All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework. Reports must be prepared in accordance with the following guidance:

- *Land Contamination Risk Management (LCRM)*

- BS 10175:2011+ A2:2017 *Investigation of Potentially Contaminated Sites. Code of Practice*
- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020* by the Yorkshire and Lincolnshire Pollution Advisory Group.

The conditions relate to Planning Control only. Approval under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further information. Any other necessary consent must be obtained from the appropriate authority. If the applicant commences work without discharging conditions, they will be at risk of enforcement action and invalidating the permission if the planning condition is a pre commencement condition.

EVF1 Electric Vehicle Charging Points – Footnote

- The electrical supply of the final installation should allow the charging equipment to operate at full rated capacity and the installation must comply with all applicable electrical requirements in force at the time of installation.
- Approval of EVCPs under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further information in relation to Approved Document S.