



THIS FORM IS FOR USE BY ELECTRICITY NETWORK OPERATORS TO ADVISE LOCAL PLANNING AUTHORITIES OF PROPOSED WORKS TO BE UNDERTAKEN WITHIN THEIR DESIGNATED AREA THAT ARE CONSIDERED TO BE EXEMPTED UNDER THE OVERHEAD LINES(EXEMPTION)(ENGLAND AND WALES) REGULATIONS 2009. LOCAL AUTHORITIES HAVE THE RIGHT TO INVOKE THE FULL SECTION 37 PROCESS UNDER THE ELECTRICITY ACT 1989 SHOULD IT BE CONSIDERED NECESSARY.

The Form should be sent in triplicate to each Local Planning Authority in whose area the proposed development would be situated.

#### DETAILS OF APPLICANT

Name: NORTHERN POWERGRID (YORKSHIRE) PLC

Contact person: Lynn Webster

Address: Northumbria Works

Mill Street East

Dewsbury

WF12 9AH

Telephone No:

Applicant's reference: ENQ23181075

Date: 21 August 2024

**To: Kirklees Metropolitan Council, Planning Services, P.O Box 1720,  
Huddersfield. HD1 9EL**

#### **Electricity Act 1989: Overhead Lines (Exemption)(England and Wales) Regulations 2009**

It is proposed to undertake the following work that is considered to be exempted from the Electricity Act 1989 by falling within the Overhead Lines (Exemption)(England and Wales) Regulations 2009:

#### **Electricity Supply –**

1. Replace an existing (Age Expired) Single Wooden Terminal Pole with a Wooden H-Pole (Double Pole) and replace an existing 100kVA Transformer with a 200kVA Transformer onto the new H-Pole.

This apparatus is required to provide increased electrical load to the Yorkshire Water site at:

Meltham Sewage Treatment Works  
Bentley Road  
Meltham  
Huddersfield  
HD9 4AP

The location of the new pole and transformer has been chosen so as to cause minimum disruption and is considered to be the most acceptable.

The Council/Authority is requested to indicate that it has no objection to the work being carried out by returning two copies of this Form with the Certificate completed and signed.

Yours faithfully

Lynn Webster 

For and on behalf of the Applicant

Applicant's ref:	ENQ23181075	Location/scheme:	Meltham Sewage Treatment Works. Huddersfield HD9 4AP.
------------------	-------------	------------------	--



CERTIFICATE

**TO BE COMPLETED BY THE LOCAL PLANNING AUTHORITY AND  
RETURNED TO THE APPLICANT ELECTRICITY NETWORK COMPANY  
WITHIN SIX WEEKS OF RECEIPT**

**Kirklees Metropolitan Council, Planning Services, P.O Box 1720, Huddersfield.  
HD1 9EL**

**\*(i) objects/does not object for the proposed development detailed above to be  
undertaken under the exemptions laid down in the Overhead Lines  
(Exemption)(England and Wales) Regulations 2009**

**\* (ii) wishes/does not wish the Secretary of State to consider the application using  
the full section 37 process under the Electricity Act 1989**

**\*The reasons for requesting the full section 37 process are:**

**Dated:**

**Signed:  
Designation  
(On behalf of Kirklees Council)**

**\*delete as appropriate**