

**Consultation Response from: KC Environmental Health (Pollution & Noise Control)**

**2024/92476 - Herbert Brown House, 50-52, Whiteley Street, Milnsbridge, Huddersfield, HD3 4LT**

**Discharge of details reserved by conditions 4 (noise assessment), 6 (ingress and egress) on previous permission 2024/90305 for change of use from Class B2 Industrial unit to Class E(d) Indoor sport & recreation (cricket coaching facility) (within a Conservation Area)**

**Responding Date:  
26 September 2024**

**Responding Officer:  
Mohammed Nasim**

**Responding Ref:  
WK202428451**

Note – These comments relate to Condition 4 (Noise Assessment) ONLY

**Comments**

**Condition 4 (Noise Assessment)**

The applicant has submitted a Noise assessment authored by Martin Environmental Solutions dated August 2024 Ref 2784-1. Para 1.2 of the report identifies the neighbouring area as shown in figure 1 with particular reference to the residential noise sensitive receptors (NSRs).

A background noise survey was conducted between the 23<sup>rd</sup> and the 25<sup>th</sup> of July 2024 from two monitoring positions as stated in para 3.4. A summary of the findings are given in the tables in para 3.7. Road traffic was the dominant source. Using library data for typical cricketing use, calculations have been used to determine the level of generated noise to the nearest NSRs. After allowing for the sound reduction values of the existing structure, the report determines a low impact from the internal use. Consideration has been given to the car drop off/pick up, and based upon library data, the report states due to the high measured levels, this too would result in a low impact.

The findings of the report are accepted.

**Recommendations**

**Condition 4 (Noise Assessment)**

The findings of the report area accepted and we recommend the condition can be discharged.