Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2024/92568 Land off Manchester Road, Marsden, Huddersfield, HD7 6NJ		
Erection of agricultural shed including access and associated works		
Responding Date: **26th November 2024**	**Responding Officer:** **SR**	**Responding Ref:** **WK202436338**

Comments

We have reviewed the application and supporting information, we offer the following comments. The application concerns a 12m by 12m agricultural building it will have a 2.0m dry stone plinth with Yorkshire boarding to all elevations to provided ventilation and a profiled steel sheeting roof. The site of the proposed development is not on land identified as potentially contaminated it is however within 500m of a former landfill site and a former quarry which may have been infilled.

We have reviewed this application and supporting documents and do not consider there to be any significant Environmental Health impacts with this development, however, remind the applicant that any attempt to encapsulate the building would alter the natural ventilation afforded by the current design any may expose future occupants to unidentified risks.