
Sent: Thursday, September 12, 2024 12:19 PM

Subject: RE: Attached letter from Kirklees Council regarding application number 2024/92576 at location site of, Former Spotted Cow Pub, New Hey Road, Oakes, Huddersfield, HD3 4BU

I would like to advise that planning condition 21 (retaining walls) can not be discharged, as the supporting information does not include the required dimensioned sectional details along the highway boundary to determine whether the design of proposed highway retaining structure will be liable to a formal technical approval via submission of an AIP.

Regards

Farhad Khatibi

Bridges & Structures Manager
Structures Section
Highways and Streetscene
Kirklees Council

Highways and Streetscene | Highways Structures | Civic Centre 1 | High Street | Huddersfield | HD1 2NF

 **External:** 01484 221000 **Internal:** 74199

Mobile: None

✉ **Email:** farhad.khatibi@kirklees.gov.uk

