

**Consultation Response from Alan Smith,
KC Waste Strategy (Refuse & Recycling)**

2024/92727 Land adjacent to, Ashbourne Drive, Liversedge

Erection of residential development 67 dwellings with associated access, parking, public open space, landscaping and infrastructure

Date Responded: 24/12/2025

Responding Officer: Alan Smith

Responding Ref: WPN 25 044

1. Introduction

This response is provided by the Waste Collection Authority (WCA) and outlines operational requirements for waste storage and collection. These comments aim to support compliance with Kirklees Local Plan policies LP24 (d.vi), LP43, and the Highway Design Guide SPD. The aim is to achieve a safe and efficient waste collection service.

Section 45(1)(a) of the Environmental Protection Act 1990 places a duty on the Waste Collection Authority (WCA) to arrange for the collection of household waste within its area. Regardless of whether a private contractor is engaged, the WCA must ensure that there is adequate on-site waste storage capacity, suitable access for collection vehicles, and that, should the responsibility for collection revert to the WCA in the future, the process can be carried out efficiently.

The Council takes the issue of bin blight seriously and encourages developers to ensure that the street scene for new developments is not spoilt by the poor design for refuse storage and collection.

2. Waste Storage Requirements

Each dwelling must accommodate:

- **3 x 240 L wheeled bins for:**
 - Residual waste – collected on alternative weeks
 - Recyclable waste – collected on alternative weeks
 - Garden waste – paid for service collected fortnightly (or future Simpler Recycling legislation provision)
- **Bin space dimensions:**
 - floor space required is 940 mm x 780 mm per bin
- **Bin storage location:**
 - Must not obstruct highways or driveways
 - Be in rear gardens, gated access must be secure and wide enough for bins to pass through
 - No gradients steeper than 1:12 or steps
 - Bins must be suitably screened when stored at the front or properties
- **Composting:**
 - As the properties have a garden the developer is encouraged to provide compost bins to help meet better meet the council's 'clean and green' objectives for waste reduction

3. Bin Collection Points (BCPs)

- Must be shown on a layout plan for all properties
- No gradients steeper than 1:12 or steps from storage area to BCP
- Located adjacent to an adoptable highway
- Solid surface required, resistant to constant wear and tear
- The maximum drag out distance from bin storage area to BCP is 25 m (BS5906:2005)
- Temporary BCPs may be needed for early occupiers whilst site is being built (likely collection area would be adjacent to Ashbourne Drive or Ashbourne Way)

- Site specific comments
 - Plots 56 to 59 and 63 – confirmation is required of the bin screening for these properties as bins are located at the front of properties.
 - Plots 6 to 9, 14, 15 and 26 to 35 – confirmation is required that there are no steps between the bin storage area and BCP

4. Refuse Collection Vehicle (RCV) Access

- The WCA will not enter:
 - Private drives
 - Roads not built to an adoptable standard
 - Active construction sites
- Road layout must:
 - Enable looped access (preferred over cul-de-sacs)
 - Where applicable, turning heads must be suitable for an 11.85m RCV
 - Turning areas must be made active to avoid them being used for additional parking
- Reversing distance for an RCV must not exceed 12m (WISH guidance)

5. Phased Development Considerations

For phased occupation:

- Temporary waste storage and collection arrangements must be approved prior to first occupation
- WCA will not collect from incomplete sites
- Developers must bulk order bins for residents via: trade.waste@kirklees.gov.uk

6. Requested Planning Conditions

- **Pre-Occupation Waste Strategy**
Prior to commencement the developer must submit for approval details for bin storage, screening, BCPs, and RCV access. The approved details shall be provided before first occupation and shall be so retained thereafter.
- **Phased Occupation Waste Management**
Prior to commencement the developer must, where applicable, submit for approval temporary waste collection arrangements if the site becomes occupied prior to completion. The approved details shall be provided before first occupation and shall be so retained thereafter.

7. Policy Context

- **LP24 (d.vi):** Requires unobtrusive, well-designed waste facilities
- **LP43:** Supports waste minimisation and recovery
- **National Planning Policy for Waste (5.8):** Adequate storage facilities at residential premises

8. Design Guidance References

- [Waste Management Design Guide for New Developments](#)
- [Kirklees Highway Design Guide SPD](#)
- [Kirklees Local Plan Strategy and Policies](#)
- [Avoiding Rubbish Design Guide](#)
- [Building for a Healthy Life \(2020\)](#)

- [Building Regulations 2010 Part H6](#)
- [Safety Distances Between Waste Containers and Buildings](#)
- BS5906:2005 Waste Management in Buildings