

**Consultation Response from KC,
Highways Development Management**

2024/92779 land at Providence Street, Earlsheaton, Dewsbury, WF12 8HZ

Outline application for residential development

Date Responded: 9-6-2025.

Responding Officer: Mark Berry.

Responding Ref: 15-6SE-13.

The highways consultation response dated 8th April concluded that the refuse vehicle swept paths were far too tight to kerb lines and were not considered acceptable.

The applicants have now provided revised plan number 24023.ATR/01 showing 7.5m junction radii and revised refuse vehicle swept paths.

Unfortunately, the swept path drawing does not provide any movements from the south-eastern side and given that Providence Street is not a one-way street, and we need to consider the other approach also.

Please ask the applicants to provide swept paths that show all vehicle movements at the junctions.

