

Consultation Response from: KC Environmental Health (Pollution & Noise Control)

2024/92807 - 42 Storthes Hall Lane, Kirkburton, Huddersfield, HD8 0PT

Installation of air source heat pump

**Responding Date:
24 October 2024**

**Responding Officer:
Mohammed Nasim**

**Responding Ref:
WK202432709**

Comments

The submitted MCS 020 Certificate shows the proposed installation fails to meet with the requirements of the Microgeneration scheme. As such, we cannot support the application.

The applicant will need to seek the advice of an acoustic consultant should they wish to proceed with the application. All noise assessments should be carried out by a competent person. The applicant may wish to contact the Association of Noise Consultants <http://www.association-of-noise-consultants.co.uk/> (020 8253 4518) or the Institute of Acoustics <http://www.ioa.org.uk> (0300 999 9675) for a list of members.