

**Consultation Response from KC,
Lead Local Flood Authority**

2024/92842 Land to North and South of, Crossley Lane, Dalton, Huddersfield, HD5 0QP

Discharge of details reserved by conditions 3 (drainage) and 4 (adoptable estate roads) of previous Reserved Matters approval 2020/90805 pursuant to outline permission 2015/90430 for erection of residential development comprising (Use Class C3) and incorporating associated new access (to Crossley Lane and Cold Royd Lane) and associated works (122 dwellings)

Date Responded: 10th November 2024

Responding Officer: Paul Farndale

Responding Ref:

Condition 3 – Drainage Details

A plan and cross section of the attenuation tank is required to accompany details already provided.

This condition should NOT be discharged at this moment in time.