

**Consultation Response from: KC Environmental Health (Pollution & Noise Control)**

**2024/92954 - 23 Tanyard Road, Oakes, Huddersfield, HD3 4YW**

**Installation of air source heat pump**

**Responding Date:  
19 November 2024**

**Responding Officer:  
Mohammed Nasim**

**Responding Ref:  
WK202435307**

**Comments**

The applicant has submitted a noise assessment from Aira Home dated 10 October 2024 which shows the proposed installation meets with the MCS 020 scheme. We therefore have no objection to the installation.