Kirklees COUNCIL

Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2024/92976 - Greenhead College, Greenhead Road, Huddersfield, HD1 4ES		
Discharge of details reserved by conditions 22 and 27 (noise), 31 (landscaping) of permission 2021/93674 for partial redevelopment of Greenhead College including demolition and making good, erection of 2 and 4 storey buildings, reconfiguration of parking and access arrangements, reconfiguration of sports provision and other associated external works (within a Conservation Area)		
Responding Date: **15 November 2024**	**Responding Officer:** **Mohammed Nasim**	**Responding Ref:** **WK202434598**

Note – These comments relate to conditions 22 and 27 ONLY.

Comments

The applicant has submitted a Memo from Apex Acoustics dated 09 September 2024 Ref NE8659-APX-02-ZZ-RP-YA-0006-P01 as an addendum to the Noise Impact Assessment Report (ref. NE8659-APX-ZZ-ZZ-RP-YA-0004 as approved to discharge Condition 22 under ref. 202391192. It is submitted following the replacement of plant as identified in para 2.2 and relocation of plant as identified in para 2.8.

Based upon measured background levels and the manufacturers noise levels, modelling has been conducted as shown in figure 2 which shows it meets with the requirements of the approved Noise Impact Assessment.

The findings are accepted.

Recommendations

Condition 22

Subject to the relevant aspect of the condition, we recommend this part of the condition can be discharged.

Condition 27

Subject to the phasing of the development, we recommend this part of the condition can be discharged.