

**Consultation Response from KC,
Lead Local Flood Authority**

2024/93189 Unit 19-20, Headfield Mills, Savile Road, Savile Town, Dewsbury, WF12 9LQ

Erection of single storey extension, external alterations to shopfront to front and side elevation, change of use of part vacant area into class E Cafe and formation of car park access

Date Responded: 22nd March 2026

Responding Officer: Paul Farndale

Responding Ref: 1

Kirklees Flood Management & Drainage can SUPPORT this application.

The sequential test submitted is to do with a test regarding retail and not flood risk.

A change of use does not require a flood risk sequential test.

Commercial extensions of less than 250 sq m do not require a sequential test.

The use of car parking area is small and, in this instance, would not benefit from attenuation.