

**Consultation Response from: KC Environmental Health (Pollution & Noise Control)**
**2024/93336 209 Scar Lane, Milnsbridge, Huddersfield, HD3 4PZ**
**Erection of detached building to create dwelling forming annex accommodation associated with 209, Scar Lane, Milnsbridge, Huddersfield, HD3 4PZ**
**Responding Date:  
December 2024**
**Responding Officer:  
SR**
**Responding Ref:  
WK2024**
**Comments**

We have reviewed the application and supporting information, we offer the following comments. The application concerns the erection of a single detached residential dwelling on what appears to be garden land of an existing dwelling.

**Contaminated Land**

The proposed development is shown on our mapping systems to be located adjacent to the site of a former quarry, listed as landfill (our site ref: 409/9).

Whilst we have no objection to the application, we recommend conditions in relation to contaminated land to ensure the site is safe and suitable for the proposed development.

**Construction Related Noise**

The proposed site is adjacent to an existing dwelling, we recommend a condition to ensure construction noise associated with the proposal does not cause loss of amenity to existing residents.

**Recommended Conditions**
**CLC1 Submission of a Phase 1 Preliminary Risk Assessment Report - Condition**

Groundworks shall not commence until actual or potential land contamination at the site has been investigated and a Preliminary Risk Assessment (Phase I Desk Study Report) by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

**CLC2 Submission of a Phase 2 Intrusive Site Investigation Report - Condition**

Where further intrusive investigation is recommended in the Preliminary Risk Assessment approved pursuant to condition (CLC1) groundworks (other than those required for a site investigation report) shall not commence until a Phase II Intrusive Site Investigation Report by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

**CLC3 Submission of Remediation Strategy - Condition**

Where site remediation is recommended in the Phase II Intrusive Site Investigation Report approved pursuant to condition (CLC2) further groundworks shall not commence until a

Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

#### **CLC4 Implementation of the Remediation Strategy - Condition**

Remediation of the site shall be carried out and completed in accordance with the Remediation Strategy approved pursuant to condition (CLC3). In the event that remediation is unable to proceed in accordance with the approved Remediation Strategy or contamination not previously considered [in either the Preliminary Risk Assessment or the Phase II Intrusive Site Investigation Report] is identified or encountered on site, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Works shall not recommence until proposed revisions to the Remediation Strategy have been submitted to and approved in writing by the Local Planning Authority. Remediation of the site shall thereafter be carried out in accordance with the approved revised Remediation Strategy.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

#### **CLC5 Submission of Verification Report - Condition**

Following completion of any measures identified in the approved Remediation Strategy or any approved revised Remediation Strategy a Verification Report by a suitably competent person shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as the remediation measures have been completed for the site in accordance with the approved Remediation Strategy or the approved revised Remediation Strategy and a Verification Report in respect of those remediation measures has been approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 183 and 184 of the National Planning Policy Framework

#### **CLC7 Contaminated land - Footnote**

All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework 2021. Reports must be prepared in accordance with the following guidance:

- Land Contamination Risk Management (LCRM)
- BS 10175:2011+ A2:2017 Investigation of Potentially Contaminated Sites. Code of Practice
- Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020 by the Yorkshire and Lincolnshire Pollution Advisory Group.

The conditions relate to Planning Control only. Approval under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further information. Any other necessary consent must be obtained from the appropriate authority. If the applicant commences work without discharging conditions, they will be at risk of

enforcement action and invalidating the permission if the planning condition is a pre commencement condition.

**CSC1 Construction Site Working Times - Condition**

No construction related noise shall be audible beyond the site boundary outside the hours of:

- 07.30 to 18.30 hours Mondays to Fridays
- 08.00 to 13.00 hours Saturdays

With no construction related noise audible beyond the site boundary on Sundays or Bank/Public Holidays.

Reason: To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and LP52 of the Local Plan

**CSF1 Construction Sites working times – Footnote**

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited.