

**Consultation Response from: KC Environmental Health (Pollution & Noise Control)**

2024/93359 - Brayside, 71, Coach Road, Cowcliffe, Huddersfield, HD2 2NW

**Demolition of existing dwelling and garage and erection of detached dwelling with detached garage**
**Date Responded:**  
 7<sup>th</sup> January 2025

**Responding Officer:**  
 NH

**Responding Ref:**  
 WK/202440402

**Contaminated Land**

The proposed development site is not shown to be on land identified as potentially contaminated by its previous use, it is however shown as being close to historical quarries. The development involves demolition of an existing property and groundworks, we therefore recommend a condition in relation to unexpected contamination.

**Construction Noise**

Construction noise can give rise to loss of amenity to neighbouring noise sensitive receptors, for this reason a condition is necessary to limit the hours of operation for the site

**Electric Vehicle Charging Points**

We note that parking is proposed at this development. We would encourage any electric vehicle charging points installed as part of this development to meet the requirements of the Air Quality & Emissions Technical Planning Guidance from the West Yorkshire Low Emissions Strategy Group. The applicant should note the information in the recommended Electric Vehicle Charging Points Footnote.

**Recommended Conditions**
**CLC6 Reporting of Unexpected Contamination - Condition**

If contamination, or the presence of coal not previously identified by the developer prior to the grant of this planning permission is encountered during the development, all works in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Works in the affected area shall not recommence until either (a) a Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority or (b) the Local Planning Authority has confirmed in writing that remediation measures are not required. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures. Thereafter remediation of the site shall be carried out and completed in accordance with the approved Remediation Strategy. Following completion of any measures identified in the approved Remediation Strategy a Verification Report shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as that part of the site has been remediated in accordance with the approved Remediation Strategy and a Verification Report in respect of those works has been approved in writing by the Local Planning Authority.

**Reason:** To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 196 and 197 of the National Planning Policy Framework.

**CLC7 Contaminated land - Footnote**

All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework. Reports must be prepared in accordance with the following guidance:

- *Land Contamination Risk Management (LCRM)*
- *BS 10175:2011+ A2:2017 Investigation of Potentially Contaminated Sites. Code of Practice*
- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020* by the Yorkshire and Lincolnshire Pollution Advisory Group.

The conditions relate to Planning Control only. Approval under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further information. Any other necessary consent must be obtained from the appropriate authority. If the applicant commences work without discharging conditions, they will be at risk of enforcement action and invalidating the permission if the planning condition is a pre commencement condition.

### **CSC1 Construction Site Working Times - Condition**

No construction related noise shall be audible beyond the site boundary outside the hours of:

- 07.30 to 18.30 hours Mondays to Fridays
- 08.00 to 13.00 hours Saturdays

With no construction related noise audible beyond the site boundary on Sundays or Bank/Public Holidays.

**Reason:** To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and LP52 of the Local Plan

### **CSF1 Construction Sites working times – Footnote**

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited

### **EVF1 Electric Vehicle Charging Points – Footnote**

- The electrical supply of the final installation should allow the charging equipment to operate at full rated capacity and the installation must comply with all applicable electrical requirements in force at the time of installation.
- Approval of EVCPs under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further information in relation to Approved Document S.

