

Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2024/93365 The Leslie Foundation, The Pavilion, Storthes Hall Park, Storthes Hall Lane, Kirkburton, Huddersfield, HD8 0WA		
Erection of hockey changing rooms		
Responding Date: 13th December 2024	Responding Officer: SR	Responding Ref: WK202439038
<p><u>Comments</u> We have reviewed the application and supporting information, we offer the following comments. The application concerns replacement modular changing facilities to be placed onto the existing hardstanding.</p> <p><u>Pre determination information required</u> Whilst we have no objection, the proposed facilities show toilets and showers. We therefore require information on how water will be supplied to site and what facilities for disposing of foul water will be provided. If it is the intention to provided drinking water, which I assume will be the case, given it's a sports facility and athletes will need to rehydrate. We require confirmation as to the quality of said water.</p> <p>We require this information to prevent loss of amenity by way of foul effluent polluting the local environment and impacting drinking water quality, to accord with the aims of the Kirklees Local Plan LP34 and LP52 and Chapters 15 of the National Planning Policy Framework.</p> <p>In relation to a wholesome drinking water supply: we require this information to prevent future users of the development from being put at unacceptable risk from poor drinking water quality, to accord with the accord with the aims of the Kirklees Local Plan LP34 and LP52 and Chapters 15 of the National Planning Policy Framework.</p>		