



YorkshireWater

Mathias Franklin
Head of Planning Services
Kirklees Metropolitan District Council
P.O. Box B93
Civic Centre
Huddersfield
HD1 2JR

Yorkshire Water Services
Developer Services
Sewerage Technical Team
PO BOX 52
Bradford
BD3 7AY

Tel: 0345 120 8482

Email:
planningconsultation@yorkshirewater.co.uk

Your Ref: 2024/93418
Our Ref: A005724

16th December 2024

Dear Sir/Madam,

Rose And Crown Inn, 132 Knowl Road, Golcar, Huddersfield – Discharge of details reserved by conditions 9, 10 and 13 (foul and surface water drainage details) on previous permission 2024/90839 for erection of 7 dwellings and associated infrastructure following partial demolition of existing public house

Thank you for consulting Yorkshire Water regarding the above proposed development. We have the following comments:

Waste Water

Yorkshire Water objects to the discharge of condition 9, 10 13.

1.) The drainage details submitted on drawing 'Drainage Strategy' 24247-DR-C-0100 (revision P1) dated 21/06/24 that has been prepared by Dart require amendments. The following point(s) should be addressed:

a.) evidence should be submitted to show that other (than discharge to public sewer) means of surface water disposal have been considered and why they have been discounted.

Yours faithfully

Reuben Thornton
Developer Services Team

