

Mathias Franklin
Head of Planning Services
Kirklees Metropolitan District Council
P.O. Box B93
Civic Centre
Huddersfield
HD1 2JR

Yorkshire Water Services
Developer Services
Sewerage Technical Team
PO BOX 52
Bradford
BD3 7AY

Tel: 0345 120 8482

Email:
planningconsultation@yorkshirewater.co.uk

Your Ref: 2025/90033
Our Ref: A008369

5th June 2025

Dear Sir/Madam,

adj, 916, Halifax Road, Hartshead Moor, Cleckheaton – (KIRK) Erection of 11 dwellings with access from Halifax Road and associated works

Thank you for consulting Yorkshire Water regarding the above proposed development. We have the following comments:

Waste Water

If planning permission is to be granted, the following conditions should be attached in order to protect the local aquatic environment and Yorkshire Water infrastructure:

**The development shall be carried out in accordance with the details shown on the submitted plan, "Drainage Strategy' 22091-DSR-001 (rev A) prepared by Avant, dated 13/05/25", unless otherwise agreed in writing with the Local Planning Authority.
(In the interest of satisfactory and sustainable drainage)**



YorkshireWater

1.) The submitted 'Drainage Strategy' 22091-DSR-001 (rev A) prepared by Avant, dated 13/05/25 is acceptable

In summary, the report states that

- a.) Foul water will discharge to public foul water sewer
- b.) Sub-soil conditions do not support the use of soakaways
- c.) A watercourse is remote from the site
- d.) Surface water will discharge to public surface water sewer via storage with restricted discharge of 3.5 litres/second.

2.) If the developer is looking to have new sewers included in a sewer adoption agreement with Yorkshire Water (under Section 104 of the Water Industry Act 1991), he/she should contact our Developer Services Team (telephone 03451 208 482, email: technical.sewerage@yorkshirewater.co.uk) at the earliest opportunity. Sewers intended for adoption should be designed and constructed in accordance with the WRC publication 'Code for Adoption - a design and construction guide for developers' as supplemented by Yorkshire Water's requirements.

Yours faithfully

Reuben Thornton
Developer Services Team

