

**Consultation Response from KC,  
Lead Local Flood Authority**

**2025/90033 adj, 916, Halifax Road, Hartshead Moor, Cleckheaton, BD19 6LR**

**Erection of 12 dwellings with access from Halifax Road and associated works**

**Date Responded: 02/12/2025.**

**Responding Officer: Martin Stephenson**

**Responding Ref: 2**

**Previous response by the LLFA**

Dated 13/06/2025 for application 2025/90033

**Documents reviewed by the LLFA:**

Advant Engineering:

- 22091-DSR-001, Drainage Strategy, Rev B dated 20/10/2025.
- 22091-104, S104 Drainage Layout Plan, Rev B dated 10/10/2025.

**Drainage Summary:**

The Drainage Layout Plan refers to a 72mm diameter hydrobrake which is not acceptable (as noted in the LLFA's previous response). Please revise the drawing and re-submit to the Planning Officer.

The previous LLFA consultation requested confirmation that permission from the 3<sup>rd</sup> party landowner that the outfall from the site can cross the field outside of the site boundary – this confirmation has not been given.

The LLFA confirms that the hydraulic calculations are accepted.

**Kirklees Flood Management and Drainage as Lead Local Flood Authority, OBJECTS to this planning application and requires FURTHER INFORMATION is provided as noted above**