

Consultation Response from: KC Environmental Health (Pollution & Noise Control)
2025/90052 - adj, 21a, Jagger Lane, Emley Moor, Huddersfield, HD8 9SY
Erection of detached dwelling
Date Responded:
6th February 2025
Responding Officer:
NH
Responding Ref:
WK/202503127
Contaminated Land

Our records indicate that the site is on potentially contaminated land (our reference 157/17) due to historical land uses. We acknowledge the submission of a Coal Mining Risk Assessment by Lyons CMC (24th January 2024, CMRA 00386). The report includes geotechnical information, which falls outside the scope of Environmental Health. As such, this consultation response focuses solely on the land contamination aspects of the report.

The report identifies a potential risk from coal mining features and recommends additional investigations to establish the ground conditions and risk to the development. Considering our records and the report provided, we consider full contaminated land conditions to be necessary.

Noise

The proposed development appears to be located near a depot. As a result, sensitive receptors would be situated close to potential noise sources. If a depot is located close to the site, we would recommend a condition requiring a noise assessment report to be submitted.

Construction Times

Construction can give rise to loss of amenity to neighbouring sensitive receptors, for this reason a condition is necessary to limit the hours of operation for the site.

Electric Vehicle Charging Points

We note that parking is proposed at this development. We would encourage any electric vehicle charging points installed as part of this development to meet the requirements of the Air Quality & Emissions Technical Planning Guidance from the West Yorkshire Low Emissions Strategy Group. The applicant should note the information in the recommended Electric Vehicle Charging Points Footnote.

Recommended Conditions
CLC1 Submission of a Phase 1 Preliminary Risk Assessment Report - Condition

Groundworks shall not commence until actual or potential land contamination at the site has been investigated and a Preliminary Risk Assessment (Phase I Desk Study Report) by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 196 and 197 of the National Planning Policy Framework

CLC2 Submission of a Phase 2 Intrusive Site Investigation Report - Condition

Where further intrusive investigation is recommended in the Preliminary Risk Assessment approved pursuant to condition (CLC1) groundworks (other than those required for a site

investigation report) shall not commence until a Phase II Intrusive Site Investigation Report by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 196 and 197 of the National Planning Policy Framework

CLC3 Submission of Remediation Strategy - Condition

Where site remediation is recommended in the Phase II Intrusive Site Investigation Report approved pursuant to condition (CLC2) further groundworks shall not commence until a Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 196 and 197 of the National Planning Policy Framework

CLC4 Implementation of the Remediation Strategy - Condition

Remediation of the site shall be carried out and completed in accordance with the Remediation Strategy approved pursuant to condition (CLC3). In the event that remediation is unable to proceed in accordance with the approved Remediation Strategy or contamination not previously considered in either the Preliminary Risk Assessment or the Phase II Intrusive Site Investigation Report is identified or encountered on site, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Works shall not recommence until proposed revisions to the Remediation Strategy have been submitted to and approved in writing by the Local Planning Authority. Remediation of the site shall thereafter be carried out in accordance with the approved revised Remediation Strategy.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 196 and 197 of the National Planning Policy Framework

CLC5 Submission of Verification Report - Condition

Following completion of any measures identified in the approved Remediation Strategy or any approved revised Remediation Strategy a Verification Report by a suitably competent person shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as the remediation measures have been completed for (that part of) the site in accordance with the approved Remediation Strategy or the approved revised Remediation Strategy and a Verification Report in respect of those remediation measures has been approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 196 and 197 of the National Planning Policy Framework

CLC7 Contaminated land - Footnote

All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework. Reports must be prepared in accordance with the following guidance:

- *Land Contamination Risk Management (LCRM)*

- BS 10175:2011+ A2:2017 *Investigation of Potentially Contaminated Sites. Code of Practice*
- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020* by the Yorkshire and Lincolnshire Pollution Advisory Group.

The conditions relate to Planning Control only. Approval under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further information. Any other necessary consent must be obtained from the appropriate authority. If the applicant commences work without discharging conditions, they will be at risk of enforcement action and invalidating the permission if the planning condition is a pre commencement condition.

NC9 Noise Assessment Report and Mitigation Scheme - Condition

Before any enabling or construction work commences, a report specifying the measures to be taken to protect the development from noise from all significant noise sources that are likely to affect the proposed development including any commercial premises shall be submitted to and approved in writing by the Local Planning Authority.

The report shall:

- a. Determine the existing noise climate
- b. Predict the noise climate in living rooms and gardens (daytime), bedrooms (night-time) and other habitable rooms of the development
- c. Detail the proposed attenuation/design necessary to protect the amenity of the occupants of the new residences (including ventilation if required).

The development shall not be occupied until all works specified in the approved report have been carried out in full and such works shall be thereafter retained.

Reason: To protect the amenity of occupiers of the proposed development from noise or disturbance from nearby noise generating premises to accord with the aims of Policies LP24 and LP52 of the Kirklees Local Plan and Chapters 12 and 15 of the National Planning Policy Framework.

NF4 Competent Person - Footnote

All noise assessments should be carried out by a competent person. The applicant may wish to contact the Association of Noise Consultants <http://www.association-of-noise-consultants.co.uk/> (020 8253 4518) or the Institute of Acoustics <http://www.ioa.org.uk> (0300 999 9675) for a list of members.

CSC1 Construction Site Working Times - Condition

No construction related noise shall be audible beyond the site boundary outside the hours of:

- 07.30 to 18.30 hours Mondays to Fridays
- 08.00 to 13.00 hours Saturdays

With no construction related noise audible beyond the site boundary on Sundays or Bank/Public Holidays.

Reason: To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and LP52 of the Local Plan

CSF1 Construction Sites working times – Footnote

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of

the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited

EVF1 Electric Vehicle Charging Points – Advisory Footnote

- Approval under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further information in relation to Approved Document S.
- The electrical supply of the final installation should allow the charging equipment to operate at full rated capacity and the installation must comply with all applicable electrical requirements in force at the time of installation.
- To futureproof the development, we would encourage the applicant to provide these in accordance with the current *Air Quality & Emissions Technical Planning Guidance* from the West Yorkshire Low Emissions Strategy (WYLES) Group