

**Consultation Response from: KC Environmental Health (Pollution & Noise Control)**

**2025/90189 - 12 Manor Park Way, Lepton, Huddersfield, HD8 0AJ**

**Installation of air source heat pump**

**Responding Date:  
18 February 2025**

**Responding Officer:  
Mohammed Nasim**

**Responding Ref:  
WK202503754**

**Comments**

The applicant has submitted a calculation sheet which shows that the proposed installation fails to meet with the requirements of the Microgeneration Installation Standard: MCS 020. As such, we cannot support the application. They are advised to contact the installing engineer or to contact an acoustic consultant for advice.

All noise assessments should be carried out by a competent person. The applicant may wish to contact the Association of Noise Consultants <http://www.association-of-noise-consultants.co.uk/> (020 8253 4518) or the Institute of Acoustics <http://www.ioa.org.uk> (0300 999 9675) for a list of members.