

Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2025/90226- 21, Heather Fold, Skelmanthorpe, Huddersfield, HD8 9LD		
Erection of two storey front extension		
Date Responded: 18th February 2025	Responding Officer: NH	Responding Ref: WK/202503723
<p>Contaminated Land Our records indicate that the property is within 250 metres of a historic landfill. Additionally, our records show that the pre-commencement contaminated land conditions applied to the original permission associated with 21 Heather Fold, Skelmanthorpe may not have been discharged. For these reasons, we recommend the full contaminated land conditions to ensure the safe occupation and expansion of the site.</p> <p>Construction Times Construction can give rise to loss of amenity to neighbouring sensitive receptors, for this reason a condition is necessary to limit the hours of operation for the site.</p> <p>Recommended Conditions</p> <p>CLC1 Submission of a Phase 1 Preliminary Risk Assessment Report - Condition Groundworks shall not commence until actual or potential land contamination at the site has been investigated and a Preliminary Risk Assessment (Phase I Desk Study Report) by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority. Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 196 and 197 of the National Planning Policy Framework</p> <p>CLC2 Submission of a Phase 2 Intrusive Site Investigation Report - Condition Where further intrusive investigation is recommended in the Preliminary Risk Assessment approved pursuant to condition (CLC1) groundworks (other than those required for a site investigation report) shall not commence until a Phase II Intrusive Site Investigation Report by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority. Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 196 and 197 of the National Planning Policy Framework</p> <p>CLC3 Submission of Remediation Strategy - Condition Where site remediation is recommended in the Phase II Intrusive Site Investigation Report approved pursuant to condition (CLC2) further groundworks shall not commence until a Remediation Strategy by a suitably competent person has been submitted to and approved in writing by the Local Planning Authority. The Remediation Strategy shall include a timetable for the implementation and completion of the approved remediation measures. Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 196 and 197 of the National Planning Policy Framework</p>		

CLC4 Implementation of the Remediation Strategy - Condition

Remediation of the site shall be carried out and completed in accordance with the Remediation Strategy approved pursuant to condition (CLC3). In the event that remediation is unable to proceed in accordance with the approved Remediation Strategy or contamination not previously considered in either the Preliminary Risk Assessment or the Phase II Intrusive Site Investigation Report is identified or encountered on site, all groundworks in the affected area (except for site investigation works) shall cease immediately and the Local Planning Authority shall be notified in writing within 2 working days. Works shall not recommence until proposed revisions to the Remediation Strategy have been submitted to and approved in writing by the Local Planning Authority. Remediation of the site shall thereafter be carried out in accordance with the approved revised Remediation Strategy.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 196 and 197 of the National Planning Policy Framework

CLC5 Submission of Verification Report - Condition

Following completion of any measures identified in the approved Remediation Strategy or any approved revised Remediation Strategy a Verification Report by a suitably competent person shall be submitted to the Local Planning Authority. No part of the site shall be brought into use until such time as the remediation measures have been completed for (that part of) the site in accordance with the approved Remediation Strategy or the approved revised Remediation Strategy and a Verification Report in respect of those remediation measures has been approved in writing by the Local Planning Authority.

Reason: To ensure the safe occupation of the site in accordance with Policy LP53 of the Kirklees Local Plan and paragraph nos. 196 and 197 of the National Planning Policy Framework

CLC7 Contaminated land - Footnote

All contamination reports shall be prepared by a suitably competent person, as defined in Annex 2 of the National Planning Policy Framework. Reports must be prepared in accordance with the following guidance:

- *Land Contamination Risk Management (LCRM)*
- BS 10175:2011+ A2:2017 *Investigation of Potentially Contaminated Sites. Code of Practice*
- *Development on Land Affected by Contamination - Technical Guidance for Developers, Landowners & Consultants - (v11.2) June 2020* by the Yorkshire and Lincolnshire Pollution Advisory Group.

The conditions relate to Planning Control only. Approval under the Building Regulations may also be required, and the applicant should contact their Building Control Provider for further information. Any other necessary consent must be obtained from the appropriate authority. If the applicant commences work without discharging conditions, they will be at risk of enforcement action and invalidating the permission if the planning condition is a pre commencement condition.

CSC1 Construction Site Working Times - Condition

No construction related noise shall be audible beyond the site boundary outside the hours of:

- 07.30 to 18.30 hours Mondays to Fridays
- 08.00 to 13.00 hours Saturdays

With no construction related noise audible beyond the site boundary on Sundays or Bank/Public Holidays.

Reason: To safeguard the amenities of the occupiers of nearby properties in accordance with part 15 of the NPPF and LP52 of the Local Plan

CSF1 Construction Sites working times – Footnote

Kirklees Council has powers under Section 60 of the Control of Pollution Act 1974 to control noise from construction sites and may serve a notice imposing requirements on the way in which construction works are to be carried out. It has additional powers under Sections 80 of the Environmental Protection Act 1990 to prevent statutory nuisance including noise, dust, smoke and artificial light and must serve an abatement notice when it is satisfied that a statutory nuisance exists or is likely to occur or recur. Failure to comply with a notice served using the above-mentioned legislation would be an offence for which the maximum fine on summary conviction is unlimited