

RE: Env Health Response – 2025/90387

 Paul Briggs
To: William Simcock

 Reply  Reply All  Forward  

Tue 10/02/2026 14:27

t:
e:
w: www.northerndesignpartnership.co.uk

Hi Paul,

Whilst guidance/standards suggests that testing is required, Kirklees have said on their consultation that *the applicant are advised that any fill materials, whether site won or imported, used within areas of public open space (or similar) must comply with the criteria set out in the Phase 2 report.* As the stockpiled material is to go beneath hard-standing, we deem these to not be public open space areas (or similar). However, I have advised that the topsoil will need testing when that is brought on to site further down the line.

Hope this makes sense.

Kind Regards,

Rob Palmer MSc, FGS, ACIEH
Engineering Director
Rogers Geotechnical Services Ltd




www.rogersgeotech.co.uk

 Unit 1 Manorcroft Works, Commercial Road, Skelmanthorpe, Huddersfield, West Yorkshire, HD8 9DT



WANT TO LEARN MORE? TO TAKE A LOOK AT OUR BROCHURE, [CLICK HERE](#). 

HOW DID WE DO? [CLICK HERE TO TELL US WHAT YOU THINK OF RGS SERVICE](#)  **SIGN UP TO OUR MONTHLY NEWSLETTER** [CLICK HERE NOW TO SUBSCRIBE](#) 

