

Consultation Response from: KC Environmental Health (Pollution & Noise Control)		
2025/90403 - Land Adjacent, 21 Thomas Street, Lindley, Huddersfield, HD3 3JJ		
Variation of condition 2 (plans) on previous permission 2023/91408 for erection of care home (Class C2) with sub-station, associated car parking, access, servicing, landscaping and other associated works		
Responding Date: 22 April 2025	Responding Officer: Mohammed Nasim	Responding Ref: WK202510170
<p><u>Comments</u></p> <p>Further to our comments dated 03 April 2025, the applicant submitted an e-mail with an amended Noise Impact Assessment authored by Apex Acoustics dated 03 April 2024 Ref 11233.1 Rev A attached which considered the ASHP installation. Upon review, there were a number of discrepancies identified which were relayed back to the applicant.</p> <p>The applicant submitted an e-mail dated 08 April 2025 stating <i>“Based on a statistical analysis of the background sound level data, as presented in Appendix A of the latest report, we are comfortable that 38 dB is appropriate to use for the representative background sound level. “</i></p> <p>Based upon the upper limits for both daytime and nighttime as shown in table 3, the BS4142 assessment as shown in table 7, indicates that the proposed fixed mechanical plant will meet with this criteria.</p> <p>The submitted report is accepted.</p>		