

Mathias Franklin
Head of Planning Services
Kirklees Metropolitan District Council
P.O. Box B93
Civic Centre
Huddersfield
HD1 2JR

Yorkshire Water Services
Developer Services
Sewerage Technical Team
PO BOX 52
Bradford
BD3 7AY

Tel: 0345 120 8482

Email:
planningconsultation@yorkshirewater.co.uk

Your Ref: 2025/90618
Our Ref: A008017

19th May 2025

Dear Sir/Madam,

Kirklees Council Building Services, Flint Street, Fartown, Huddersfield - (KIRK) Erection of temporary single storey office /induction building, the provision of parking for approximately 200 cars, EV charging stations and associated lighting and utilities

Thank you for consulting Yorkshire Water regarding the above proposed development. We have the following comments:

Waste Water

NOTE- it appears from the submitted site layout that buildings will be sited over the public sewerage system located within the site. This could seriously jeopardise Yorkshire Water's ability to maintain the public sewerage network and is not acceptable. We therefore OBJECT to the development layout as currently shown. I strongly advise that, prior to determination of this application, the site layout is amended to allow for adequate protection of the sewers. For further information, the developer should contact our Developer Services Team: telephone 0345 120 84 82 (option 1) or email technical.sewerage@yorkshirewater.co.uk.

Additionally Yorkshire Water objects based on lack of submitted proposed drainage information.



YorkshireWater

- 1.) The layout details submitted on drawing 'Planning Drawing Flint Street, TRU Hub' W4/VB/001 (revision FS01.3) dated 29/12/24 that has been prepared by TransPennine Route Upgrader is not acceptable. The following point(s) should be addressed:
 - a.) the submitted drawing appears to show a building proposed to be built-over the line of public sewer crossing the site -- contrary to our request
 - b.) the submitted drawing should show the site-surveyed position of the public sewer crossing the site
 - c.) the submitted drawing should show the required building stand-off from public sewer -- or an agreed alternative scheme

- 2.) On the Statutory Sewer Map, there is an unknown diameter and a 450mm diameter public combined water sewer recorded to cross the site. It is essential that the presence of this infrastructure is taken into account in the design of the scheme.
 - a.) It may not be acceptable to raise or lower ground levels over the sewer and we will not accept any inspection chambers on the sewer to be built over.
 - b.) In the instance of the unknown diameter sewer, the required stand-off distance will be subject to the surveyed diameter and depth of the asset.
 - c.) In the instance of the 450mm sewer, a stand-off distance of 5 (five) metres is required at each side of the sewer centre-line and it may not be acceptable to raise or lower ground levels over the sewer, nor to restrict access to the manholes on the sewer.
 - d.) A proposal by the developer to alter/divert a public sewer will be subject to Yorkshire Water's requirements and formal procedure in accordance with Section 185 Water Industry Act 1991.

- 3.) The developer is proposing to discharge surface water to public sewer however, sustainable development requires appropriate surface water disposal.
 - a.) Yorkshire Water promote the surface water disposal hierarchy and the developer must provide evidence to demonstrate that surface water disposal via infiltration or watercourse are not reasonably practical before considering disposal to public sewer.
 - b.) The developer and LPA are strongly advised to seek comments on surface water disposal from other drainage bodies as further restrictions may be imposed.
 - c.) As a last resort, and upon receipt of satisfactory evidence to confirm the reasons for rejection of other methods of surface water disposal, curtilage surface water may discharge to public sewer. Surface water discharges to the public sewer must have a minimum of 30% reduction based on the existing peak discharge rate during a 1 in 1 year storm event.





YorkshireWater

d.) The developer will be required to provide evidence of existing positive drainage to a public sewer from the site to the satisfaction of Yorkshire Water and the Local Planning Authority by means of physical investigation. On-site attenuation, taking into account climate change, will be required before any discharge to the public sewer network is permitted.

Yours faithfully

Reuben Thornton
Developer Services Team

