

Search application details

Application number: 2025/44/91094/E	
What is the application for?:	Discharge of details reserved by conditions 5 (foul, surface water and land drai
Address of the site or building:	127, Marsh Lane, Shepley, Huddersfield, HD8 8AS
Postcode:	

User comments

Type of comment: An objection	
Do you wish your comments to be published on the website anonymously?	Yes
I believe a foul water pumping station should not be within 4m of any walls, buildings, fences or hedges/trees. But this location S11 falls within 1-2m of walls, hedges and outbuildings. Please can the officer review this	