

Search application details

Application number: 2025/44/91094/E	
What is the application for?:	Discharge of details reserved by conditions 5 (foul, surface water and land drain)
Address of the site or building:	127, Marsh Lane, Shepley, Huddersfield, HD8 8AS
Postcode:	

User comments

Type of comment: An objection	
Do you wish your comments to be published on the website anonymously?	Yes
Can the applicant please clarify details of the type of waste water pumping station they are going to use? As there is conflicting reports online of minimum measurements which do not match up to the application. For instance Yorkshire Water suggest 15m minimum distance between a habitual building for a type 3, which this does not achieve. Its also next to existing walls and hedges. https://www.yorkshirewater.com/media7/2395/local-practice-pumping-stations.pdf Has consideration been taken for access to this pumping station in cause of a breakdown? For a type 3 pumping station a tanker is required, which I am not sure would have access? Also, can consideration be taking into account for noise, disturbance and odour from this station? This is directly next to existing properties.	