Sent: 09 July 2025 11:37

Subject: FW: Attached letter from Kirklees Council regarding application number 2025/91604 at location Huddersfield Bus Station, Upperhead Row, Huddersfield, HD1 2JN

Thank you for your request for consultation on this application. The comments are made with the intention of reducing opportunities for future crime and antisocial activity which addresses our collective responsibilities outlined in Section 17 of the Crime and Disorder Act 1998, by creating safe and secure developments where people will want to reside, visit or work.

The recommendations are supported by the following guidance:
NPPF National Planning Policy Framework (Section 8. Promoting healthy and safe communities)
https://www.gov.uk/government/publications/national-planning-policy-framework--2
Kirklees Council Planning and development policy https://www.kirklees.gov.uk/beta/planning-and-development.aspx
Kirklees Local Plan https://www.kirklees.gov.uk/beta/planning-policy/pdf/local-plan-strategy-and-policies.pdf
Secured by Design www.securedbydesign.com
Crime Prevention Through Environmental Design (CPTED)
Standards for Public Cycle Parking, June 2021 https://www.securedbydesign.com/images/05132-Cycle-Parking-and-Security-Standards-June-2021-REV-6.pdf

This advice is given as a view as to what measures might reduce the risk of crime; there can be no guarantee that the recommendations will prevent crime.

1. I have no comments or representations to make in relation to the proposed change to the size of the canopy.

2. I note that cycle parking will now consist of Sheffield stands, due to be located underneath the canopy and LED lighting; this area will also be covered by CCTV and benefit from natural surveillance. The stands should offer secure locking points for both wheels and the frame. The cycle parking area requires to be well-lit in the hours of darkness.

The stands must be either:
- fixed centrally in concrete bases 300mm x 300mm x 300mm with a minimum of 250mm embedded in the concrete base (tie bars in the legs of the stand may also be used for additional security); or where this is not possible,
- fixed to a concrete slab base or other secure surface with at least 2 anti-tamper bolts per leg and with the legs of the stand firmly welded to the base used for the fixings.

The stands should be certified to a minimum of one of the following standards:

Sold Secure SS104 Silver
LPS 2081 Issue 1 Security Rating B
STS 225 Issue 2 Burglar Resistance BR2(S)
STS 205 Issue 8 Burglar Resistance BR2
LPS 1175 Issue 8 Security Rating B3
STS 501 Security Rating TR2
STS 503 Security Rating TR2

West Yorkshire Police have no objection to this variation of conditions. We request that the advice provided above is considered and incorporated into the project, as part of crime mitigation measures which have previously been conditioned for this site.

Kind regards,

Agnieszka Boryn
Designing Out Crime Officer
Kirklees District