

From: Simon Dibbs
Sent: 21 May 2025 16:05
To: Harry Garside
Subject: Re: 3564 - Rumpus Discharge of Condition

Hi Harry,

We are installing a Mechline GreasePak unit in the main kitchen to capture anything from the wash up sink and hand wash basin. That is on top of the underground grease trap you have installed.

Kind regards

Simon Dibbs
Project Manager
Marshall Catering Equipment