

**Consultation Response from Alan Smith,
KC Waste Strategy (Refuse & Recycling)**

2025/92139 The Old Dewsbury Library, Wellington Road, Dewsbury, WF13 1HN

**Alterations to former library to form 14 apartments with associated internal and external works
(Listed Building within a Conservation Area)**

Date Responded: 16/02/2026

Responding Officer: Alan Smith

Responding Ref: WPN 25 053

1. Introduction

This response is provided by the Waste Collection Authority (WCA) and outlines operational requirements for waste storage and collection. These comments aim to support compliance with Kirklees Local Plan policies LP24 (d.vi), LP43, the Waste Management Design Guide and the Highway Design Guide SPD. The aim is to achieve a safe and efficient waste collection service.

Section 45(1)(a) of the Environmental Protection Act 1990 places a duty on the Waste Collection Authority (WCA) to arrange for the collection of household waste within its area. Regardless of whether a private contractor is engaged, the WCA must ensure that there is adequate on-site waste storage capacity, suitable access for collection vehicles, and that, should the responsibility for collection revert to the WCA in the future, the process can be carried out efficiently.

The Council takes the issue of bin blight seriously and encourages developers to ensure that the street scene for new developments is not spoilt by the poor design for refuse storage and collection.

2. Waste Storage Requirements

The total waste capacity required each week is 14 (the number of dwellings) x 180 L = 2,520 L per week. This is the equivalent of 5 x 1,100 L bins per fortnight.

The property must accommodate:

- **7 x 1,100 L wheeled bins for:**
 - 3 x Residual waste – collected on alternative weeks
 - 2 x Recyclable waste – collected on alternative weeks
 - 2 x For future Simpler Recycling legislation provision)
- **Bin space dimensions:**
 - floor space required is 1190 mm x 1575 mm per bin
- **Bin storage location:**
 - Must not obstruct highways or driveways
 - No gradients steeper than 1:12 or steps
 - Minimum 6 m clearance from fire exits, doors, and windows
 - If 6 m clearance is not feasible, adjacent structures must be fire-resistant to 30 minutes
 - Bin store must be secure to prevent theft, unauthorised use, fly-tipping, or rough sleeping

3. Bin Collection Points (BCPs)

- Due to the location and the slope the proposed collection point is not acceptable to the WCA. The bins need to be placed adjacent to the highway.
- No gradients steeper than 1:12 or steps from storage area to BCP
- Located adjacent to an adoptable highway
- Solid surface required, resistant to constant wear and tear
- The maximum drag out distance from bin storage area to BCP is 25m (BS5906:2005)

4. Refuse Collection Vehicle (RCV) Access

- The WCA will not enter:
 - Private drives
 - Roads not built to an adoptable standard
 - Active construction sites
- Reversing distance for an RCV must not exceed 12 m (WISH guidance)

5. Phased Development Considerations

For phased occupation:

- Temporary waste storage and collection arrangements must be approved prior to first occupation
- WCA will not collect from incomplete sites
- Developers must bulk order bins for residents via: trade.waste@kirklees.gov.uk

6. Requested Planning Conditions

- **Pre-Occupation Waste Strategy**
Prior to commencement the developer must submit for approval details for bin storage, screening, BCPs, and RCV access. The approved details shall be provided before first occupation and shall be so retained thereafter.
- **Bin Store maintenance**
Before development commences, details of the management and maintenance of communal refuse storage areas by a designated private management company shall be submitted to and approved by the Local Planning Authority. The approved details shall be provided before first occupation and shall be so retained thereafter.

7. Policy Context

- **LP24 (d.vi)**: Requires unobtrusive, well-designed waste facilities
- **LP43**: Supports waste minimisation and recovery
- **National Planning Policy for Waste (5.8)**: Adequate storage facilities at residential premises

8. Design Guidance References

- [Waste Management Design Guide for New Developments](#)
- [Kirklees Highway Design Guide SPD](#)
- [Kirklees Local Plan Strategy and Policies](#)
- [Avoiding Rubbish Design Guide](#)
- [Building for a Healthy Life \(2020\)](#)
- [Building Regulations 2010 Part H6](#)
- [Safety Distances Between Waste Containers and Buildings](#)
- BS5906:2005 Waste Management in Buildings