

RE: 2025/92161 - Whitehall Road West, Birkenshaw - Technical approval of oversize manholes

 Farhad Khatibi
To:  Ian Ellis,  Candy Day
Cc:  William Simcock

 Reply  Reply All  Forward  

Tue 25/11/2025 12:28

Ian

Further to a review of your latest drainage drawing nos 23-341-500-001 rev Q - Drainage Layout, 23-341-500-004 rev C - Drainage Standard Details and 23-341-EXT-002 rev A - External Works and Surface Water Tank, I can confirm that these are now considered to be satisfactory and as such Condition 21 (surface water attenuation) can now be conditionally discharged pending the submission of a suitable "Construction Compliance Certificate" together with "As built" drawing upon the completion of the drainage works.

Are you able to provide the necessary dimensioned X-sectional details for the proposed modification to the existing retaining wall abutting your site so as to enable us to advise whether these works will be liable to a formal technical approval?

Regards

Farhad Khatibi

Bridges & Structures Manager
Structures Section
Highways and Streetscene
Kirklees Council

Highways and Streetscene | Highways Structures | Civic Centre 1 | High Street | Huddersfield | HD1 2NF

📎

