

**Consultation Response from KC,
Lead Local Flood Authority**

2025/92352 Cambridge Road Car Park, Cambridge Road, Huddersfield, HD1 5BY

Formation of parking area within existing car park including associated landscaping and works

Date Responded: 19/09/2025.

Responding Officer: Martin Stephenson

Responding Ref: 1

Documents reviewed by the LLFA:

KC Highway Design:

- HD/52/61865/EXT1, Car Park Extension GA, Rev – dated Dec 2024

Drainage Summary:

The LLFA notes that the surface of the proposed car park extension is currently grass which drains through the subsoil without any reported flooding issues. Further, the proposal for the car park surfacing is a porous asphalt layer placed over 350mm thick Type 1 sub-base, thereby mimicking the current drainage method. As there will be no increase in the risk of flooding, the LLFA accepts the proposal to extend the parking area.

Kirklees Flood Management and Drainage as the Lead Local Flood Authority, SUPPORTS this application and has no recommended drainage conditions.