THIS DRAWING IS TO BE READ IN CONJUNCTION WITH :
1036-SWA-00-GF-DR-S-1102 - GROUND FLOOR STEELWORK GA
1036-SWA-00-01-DR-S-1103 - MEZZANINE AND ROOF STEELWORK GA
1036-SWA-00-ZZ-DR-S-1106 - GLAZED ELEVATION SUPPORT GA
1036-SWA-00-ZZ-DR-S-1110 - STRUCTURAL SECTIONS SHEET 1
1036-SWA-00-ZZ-DR-S-1111 - STRUCTURAL SECTIONS SHEET 2
1036-SWA-00-XX-DR-S-1500 - ISOMETRIC VIEWS

KEY TO HEALTH AND SAFETY SYMBOLS

INDICATES A RESIDUAL RISK REQUIRING A COMPULSORY ACTION.

INDICATES A RESIDUAL RISK FOR INFORMATION.

INDICATES A RESIDUAL RISK REQUIRING A PROHIBITIVE ACTION.

INDICATES A RESIDUAL RISK AS A WARNING.

ALL SETTING OUT DIMENSIONS AND LEVELS TO BE CONFIRMED BY ARCHITECTS

ALL TEMPORARY WORKS TO THE CONTRACTORS DESIGN AND DETAILS.

LEGEND : COMPOSITE DECK

DENOTES SPAN OF 120mm THICK COMPOSITE CONCRETE SLAB ON KINGSPAN MULTIDECK 60-V2 1mm GAUGE DECK. PROVIDE 1 LAYER A252 MESH THROUGHOUT TOP WITH 30mm COVER.

DENOTES SPAN OF TIMBER JOISTS WHERE APPLICABLE.

Do not scale from this drawing.
Use written dimensions only.
If in doubt ask.

Notes

GENERAL NOTES
1. DO NOT SCALE FROM THIS DRAWING.
2. ALL DIMENSIONS ARE IN MILIMETERS U.N.O.
3. ALL LEVELS ARE N METRES ABOVE ORDINANCE DATUM U.N.O.
4. THIS DRAWING IS TO BE READ IN CONJUCTION WITH ALL RELEVANT ARCHITECTS AND ENGINEERS DRAWINGS AND SPECIFICATIONS.
5. ALL BUILDING WORKS TO BE CARRIED OUT IN ACCORDANCE WITH THE BUILDING REGULATIONS (LATEST EDITION) AND THE CIVIL STRUCTURAL AND ARCHITECTURAL SPECIFICATIONS.

6. CONCRETE
a) CONCRETE TO BE GRADE C40 WITH 325Kg/m³ CEMENT CONTENT, WATER CEMENT RATIO OF 0.55 AND S3 CONSISTENCY TO BS8500 UNLESS STATED OTHERWISE.
b) ALL NON-STRUCTURAL BLINDING CONCRETE TO BE MIX GEN 1 TO BS8500 2002.
c) ALL MASS CONCRETE TO BE DESIGNATED CONCRETE MIX GEN 3 TO BS8500
d) ALL CONCRETE TO BE : DESIGN SULPHATE CLASS DS-1 AND AN ACEC CLASSIFICATION OF AC-1.
e) CONCRETE FINISHES TO BE SPECIFIED BY THE ARCHITECT.

7. REINFORCEMENT
a) ALL REINFORCEMENT BARS TO BE HOT ROLLED HIGH YIELD GRADE 500N/mm TYPE 2 DEFORMED BARS TO BS4449 2005.
b) REINFORCEMENT BARS TO BE BENT IN ACCORDANCE WITH BS8666 2005.
c) MINIMUM COVER OF 30mm TO BE PROVIDED TO SLAB AND 40mm TO BE PROVIDED TO ALL OTHER REINFORCEMENT UNLESS STATED OTHERWISE.

BYRAM ST UNIT 01 & 02 MEZZANINE SLAB GA

SCALE 1 : 100

BYRAM STREET UNIT 1 & 2 PLANT LEVEL ROOF DECK GA

SCALE 1 : 100

FIXED PITCH 04 & 05 ROOF DECK GA

SCALE 1 : 100

TYPICAL SLAB SECTION CHANGE OF SPAN TO MD60 DECKING

SCALE 1 : 20

TYPICAL SLAB EDGE SECTION PARALLEL TO SPAN OF MD60 DECKING

SCALE 1 : 20

TYPICAL SLAB EDGE SECTION PERPENDICULAR TO SPAN OF MD60 DECKING

SCALE 1 : 20

P03

LOCATION PLAN

Revision	Drawn	Checked	Approved	Modifications
P03	BG 17/07/25	MW 17/07/25	MH 17/07/25	ISSUED FOR STAGE 3 COORDINATION/PRICING. REDRAWN TO REFLECT REVISED SCHEME.
P02	BG 25/02/25	MW 25/02/25	MH 25/02/25	ISSUED FOR STAGE 3 COORDINATION/PRICING. PLANS UPDATED TO REFLECT M&E PLANT LOADING AND REVISED EXTENT OF PLANT.
P01	BG 31/01/25	MW 31/01/25	MH 31/01/25	ISSUED FOR STAGE 3 COORDINATION/PRICING.

SANDERSON WATTS ASSOCIATES
Consulting Engineers
Century House 100 Chapel Lane Wigan WN3 4HG
Tel : 01942 491777 Fax : 01942 491333
Email : swa@sandersonwatts.com
Website : www.sandersonwatts.com

Client
Kirklees COUNCIL

Project
HUDDERSFIELD MARKET

Title
OPEN MARKET MEZZANINE AND PLANT LEVEL FLOOR GENERAL ARRANGEMENT

Scale	Revision	Status Code	Original Size
As indicated	P03	S1	A1

Drg. No.
1036-SWA-00-01-DR-S-1105

Copyright Reserved to Sanderson Watts Associates
These plans and specifications are the property of Sanderson Watts Associates, and shall not be re-printed or reproduced, in whole or part, without their written consent, nor shall any building or structure be constructed in accordance with such plans and specifications or any modifications thereof without the written consent of Sanderson Watts Associates.