

DC Admin

Sent: 09 December 2025 14:23
To: Kerri Simpson; DC Admin
Subject: DOCO comments for application 2025/92836 at The Priory, Whitechapel Road, Cleckheaton, BD19 6HR

Good afternoon Kerri,

Thank you for your request for consultation. My comments are as follows.

Condition 14- security measures:

I have reviewed the revised Crime Prevention Statement and note the upgraded specification of windows and doors.

Condition is discharged.

Condition 16- lighting:

I note that bollard lighting has been removed from the 'Street Lighting' section of the Lighting Strategy document. The road and site access will be facilitated by Solar streetlights which will provide constant ambient lighting and become brighter when motion is detected.

Condition is discharged.

Kind regards,

Agnieszka Boryn
Designing Out Crime Officer
Kirklees District

This email transmission may contain confidential or legally privileged information and is intended for the addressee(s) only. If you are not the intended recipient, any disclosure, copying, distribution, retention or reliance upon the contents of this e-mail and any attachment(s) is strictly prohibited and may be unlawful. If you have received this in error, please use the reply function to notify us immediately and permanently delete the email and any attachment(s) from your computer or electronic device. West Yorkshire Police reserves the rights to routinely monitor incoming and outgoing e-mail messages and cannot accept liability or responsibility for any errors or omissions in the content and, as internet communications should not be considered as secure, for changes made to this message after it was sent. Any views or opinions expressed in this message may not be those of the West Yorkshire Police. This email was scanned for viruses by the West Yorkshire Polices' anti-

virus services and on leaving the Force was found to be virus and malware free. You must take full responsibility for any subsequent virus or malware checking.