

About the application

Application number: 2025/92882	
What is the application for?:	Erection of 75 dwellings with associated parking, infrastructure, hard and soft
Address of the site or building:	Cellars Clough Mill, Manchester Road, Marsden, Huddersfield, HD7 6LY
Postcode:	LS10 1FB

User comments

Type of comment: An objection	
Do you wish your comments to be published on the website anonymously?	Yes
The drainage strategy is flawed as the storm water storage is in the flood zone and will therefore be liable to flood water this will fill the storage system removing the storage capacity required, as a result the drainage system will back up and potentially result in flooding of the properties.	