



THIS FORM IS FOR USE BY ELECTRICITY NETWORK OPERATORS TO ADVISE LOCAL PLANNING AUTHORITIES OF PROPOSED WORKS TO BE UNDERTAKEN WITHIN THEIR DESIGNATED AREA THAT ARE CONSIDERED TO BE EXEMPTED UNDER THE OVERHEAD LINES(EXEMPTION)(ENGLAND AND WALES) REGULATIONS 2009. LOCAL AUTHORITIES HAVE THE RIGHT TO INVOKE THE FULL SECTION 37 PROCESS UNDER THE ELECTRICITY ACT 1989 SHOULD IT BE CONSIDERED NECESSARY.

The Form should be sent in triplicate to each Local Planning Authority in whose area the proposed development would be situated.

DETAILS OF APPLICANT

Name: NORTHERN POWERGRID (YORKSHIRE) PLC
Contact person: Lynn Webster
Address: Northumbria Works
Mill Street East
Dewsbury
WF12 9AH

Telephone No:

Applicant's reference: ENQ23217029

Date: 03 November 2025

To: **Kirklees Metropolitan Council, Planning Services, P.O Box 1720,
Huddersfield. HD1 9EL**

Electricity Act 1989: Overhead Lines (Exemption)(England and Wales) Regulations 2009

It is proposed to undertake the following work that is considered to be exempted from the Electricity Act 1989 by falling within the Overhead Lines (Exemption)(England and Wales) Regulations 2009:

Electricity Supply –

1. Installation of a new Single Wood Terminal Pole with two new Stay Wires onto an existing Overhead line (H1250), therefore extending the existing overhead line by One short Span just into the side boundary of a new Housing Development land plot (Harron Homes).

This apparatus is required to enable the recovery of two existing overhead line conductor spans and two existing Wood poles already on Harron Homes plot, between the proposed new terminal pole and the existing ground mounted substation (Roslyn Avenue No. 1731 Substation) and allows the developer to erect new homes on the land without the intrusion of the existing overhead line at:

Harron Homes Development
Land off Roslyn Avenue
Huddersfield
HD4 7EW

The location of the new pole and transformer has been chosen so as to cause minimum disruption to the Harron Homes Development and is considered to be the

most acceptable.

The Council/Authority is requested to indicate that it has no objection to the work being carried out by returning two copies of this Form with the Certificate completed and signed.

~~Yours faithfully~~

Redacted

Lynne Webster

For and on behalf of the Applicant

Applicant's ref:	ENQ23217029 / LW	Location/scheme:	Harron Homes Ltd , Roslyn Avenue. Huddersfield HD4 7EW.
------------------	------------------	------------------	--



CERTIFICATE

**TO BE COMPLETED BY THE LOCAL PLANNING AUTHORITY AND
RETURNED TO THE APPLICANT ELECTRICITY NETWORK COMPANY
WITHIN SIX WEEKS OF RECEIPT**

Kirklees Metropolitan Council, Planning Services, P.O Box 1720, Huddersfield.
HD1 9EL

***(i) objects/does not object for the proposed development detailed above to be undertaken under the exemptions laid down in the Overhead Lines (Exemption)(England and Wales) Regulations 2009**

*** (ii) wishes/does not wish the Secretary of State to consider the application using the full section 37 process under the Electricity Act 1989**

***The reasons for requesting the full section 37 process are:**

Dated:

**Signed:
Designation
(On behalf of Kirklees Council)**

***delete as appropriate**