

Sent: 05 December 2025 16:34

Subject: RE: Attached letter from Kirklees Council regarding application number 2025/93245 at location George Hotel, St George's Square, Huddersfield, HD1 1JA

I would like to advise that condition 17 (walls supporting the adjoining highway) can not be discharged pending the formal technical approval of design of temporary and permanent retaining structures supporting the highway via submission of AIPs.

Regards

Farhad Khatibi

Bridges & Structures Manager
Structures Section
Highways and Streetscene
Kirklees Council

Highways and Streetscene | Highways Structures | Civic Centre 1 | High Street | Huddersfield | HD1 2NF

☎ **External:** 01484 221000 **Internal:** 74199

Mobile: None

✉ **Email:** farhad.khatibi@kirklees.gov.uk



Advance notice of annual leave: