

**Consultation Response from Alan Smith,
KC Waste Strategy (Refuse & Recycling)**

2025/93385 The Bridge, 42, Market Street, Milnsbridge, Huddersfield, HD3 4HY

**Prior notification for change of use from commercial/business/service to one dwelling (within a
Conservation Area)**

Date Responded: 06/02/2026

Responding Officer: Alan Smith

Responding Ref: WPS 25 075

1. Introduction

This response is provided by the Waste Collection Authority (WCA) and outlines operational requirements for waste storage and collection. These comments aim to support compliance with Kirklees Local Plan policies LP24 (d.vi), LP43, the Waste Management Design Guide and the Highway Design Guide SPD. The aim is to achieve a safe and efficient waste collection service.

Section 45(1)(a) of the Environmental Protection Act 1990 places a duty on the Waste Collection Authority (WCA) to arrange for the collection of household waste within its area. Regardless of whether a private contractor is engaged, the WCA must ensure that there is adequate on-site waste storage capacity, suitable access for collection vehicles, and that, should the responsibility for collection revert to the WCA in the future, the process can be carried out efficiently.

The Council takes the issue of bin blight seriously and encourages developers to ensure that the street scene for new developments is not spoilt by the poor design for refuse storage and collection.

2. Waste Storage Requirements

Each dwelling must accommodate:

- **3 x 240L wheeled bins for:**
 - Residual waste – collected on alternative weeks
 - Recyclable waste – collected on alternative weeks
 - For future Simpler Recycling legislation provision
- **Bin space dimensions:**
 - floor space required is 940 mm x 780 mm per bin
- **Bin storage location:**
 - Must not obstruct highways or driveways
 - No gradients steeper than 1:12 or steps
 - At least 2.5 m away from the nearest building to avoid fire risk

3. Bin Collection Points (BCPs)

- Must be shown on a layout plan for the property, adjacent to the nearest highway
- No gradients steeper than 1:12 or steps from storage area to BCP
- Located adjacent to an adoptable highway
- Solid surface required, resistant to constant wear and tear
- The maximum drag out distance from bin storage area to BCP is 25 m (BS5906:2005)

4. Requested Planning Conditions

• **Pre-Occupation Waste Strategy**

Prior to commencement the developer must submit for approval details for bin storage, screening and BCP. The approved details shall be provided before first occupation and shall be so retained thereafter.

5. Policy Context

- **LP24 (d.vi):** Requires unobtrusive, well-designed waste facilities
- **LP43:** Supports waste minimisation and recovery

- **National Planning Policy for Waste (5.8):** Adequate storage facilities at residential premises

6. Design Guidance References

- [Waste Management Design Guide for New Developments](#)
- [Kirklees Highway Design Guide SPD](#)
- [Kirklees Local Plan Strategy and Policies](#)
- [Avoiding Rubbish Design Guide](#)
- [Building for a Healthy Life \(2020\)](#)
- [Building Regulations 2010 Part H6](#)
- [Safety Distances Between Waste Containers and Buildings](#)
- BS5906:2005 Waste Management in Buildings