

KIRKLEES STRUCTURES P.C.C. MANHOLES
 >900mm - <3000mm

- All oversize precast concrete manholes with internal diameter (0.9m < ID ≤ 3.0m) and their components including RC cover slabs intended for installation in the highway shall be designed to BS EN 1917 & BS 5911-3 and marked as such to confirm that the products represent a manufacturer's declaration that their products meet the requirement of these standards.
- All precast concrete manholes and their components shall be manufactured to Design Chemical Class (DC-4) for an intended design working life of 100 years (min).
- All reinforced concrete cover slabs must be installed with a minimum of 300mm cover to finished levels to comply with National specifications.
- The contractor will need to submit a Construction Compliance Certificate in compliance with Kirklees Council's Simplified technical approval for oversize reinforced concrete manholes with circular cover slabs with internal diameter (ID) ≤ 3.0m.

M.U.G.A
 LEVEL
 235.95

KEY

- S104 Storm water manhole
- S104 Foul water manhole
- S104 Storm water sewer
- S104 Foul water sewer
- Combined sewer
- Gully
- Yard gully
- Channel Drain (min B125 grade cover)

NOTES

ATTENTION IS DRAWN TO THE REQUIREMENTS OF THE CONSTRUCTION DESIGN AND MANAGEMENT REGULATIONS 2015 AND THE DUTIES AND RESPONSIBILITIES CONTAINED THEREIN. ALL DESIGNS ARE SUBJECT TO THE APPROVAL OF ALL RELEVANT AUTHORITIES.

- For longitudinal sections refer to drawing 425/92/06
- No services are to be sited directly over, or within 1m of, an adoptable sewer or manhole.
- Private drainage connections to adoptable sewers to be via 45° junction.
- Off site manholes already built must have invert levels checked prior to connection to the off site drainage.
- Any connections to existing sewers/manholes are to be supervised by Yorkshire Water.
- All connections to proposed public sewers to be minimum 150mm.
- Any land drain or water course on site to be diverted as not to pass under proposed buildings. Diversion to be approved and inspected on site by the Local Authority.


Adoption General Notes

- All adoptable sewer works and materials to be in accordance with Sewerage Sector Guidance (SSG), the relevant British/European and the adopting Water Authority standards/Requirements/Addendum to the Mechanical and Electrical Specification and Kitemarked.
- Manhole covers shall/must have a clear opening of 600mm and shall be Class D400 to BS EN 124 with 150mm deep frames in highways.
- Filled ground must be filled and consolidated under the supervision, and to the satisfaction, of INWL before any sewer works are carried out.
- Cover slabs must carry the BSI Kitemark or may be rejected by INWL inspector. Where the clear opening of the Kitemarked product is different to that of the cover and frame, a loading bearing slab should be fitted above the cover slab to bring the size down to 600x600mm for INWL specified cover size. Please refer to the Concrete Pipe Systems Association (CPSA), 'Technical Bulletin' issued autumn 2004 for kitemarked cover slab opening sizes.
- The adoptable sewers should be a minimum of 1m and manholes 0.5m from kerb faces and service margins.
- Sewers must have 5 metres clearance from trees and hedges, (please also refer to Figure 2.3 on page 33 in 'Sewers for Adoption' 6th Edition for restrictions on tree planting adjacent to Sewers).
- Sewers to be laid in Class 'S' bedding (150mm granular bed and surround). Where depth of cover to top of the sewer is less than 1.2m in highways and verges (or less than 900mm in none vehicular access areas) then a concrete slab should be provided above the granular bed and surround.
- Bedding and backfill material to conform to the requirement of Water Industry Specification 4-08-02 (Table A2)
- Adoptable plastic sewer pipes to be BSI Kitemarked (Certified to WS 4-35-01 and BS/EN13476). Adoptable sewer pipes to be laid in maximum 3 metre lengths unless there is a specific operational need to lay longer.
- Plastic channel sections in manholes are not acceptable and clayware is preferable. Plastic channels are difficult to set in concrete and a satisfactory finish cannot be obtained on the benching.
- The chamber size of manholes with more than one connection in them may need to be increased on an increment to accommodate the connections and bends.
- INWL's policy is not generally to accept Type 'C' brick manhole and 1050mm dia manhole rings. Instead it is preferred that you use a type 'B' manhole with 1200mm dia or 1500mm dia rings, with the opening sized over the channel where depth of cover to pipe soffit is 1-1.5m.
- If plastic pipes are to be used then the following should apply:
 - All adoptable sewers to be BSI Kitemark (certified to WS 4-35-01).
 - Bedding and backfill material to conform to the requirements of Water Industry Specification 4-08-02 (Table A2)
- Where plastic pipes are proposed for adoptable sewers, structural calculations for the plastic pipes and a site investigation report to prove that the ground condition is suitable for the plastic pipes are to be produced.
- Where plastic pipes are installed into the ground prior to getting full technical approval, the developer must provide a CCTV survey of the prospectively adoptable sewers and a deformation test (Light-Line test) of the plastic pipes.
- Demarcation chambers to be a min. 450mm chamber for 100mm foul & 150mm surface water pipes up to 1.2m deep. For depths greater than 1.2m, restricted access opening to 350mm is required for safety reasons.
- Maximum depth of demarcation chamber to be 3m, where depth exceeds 3m, manhole to be constructed as type B manhole.
- Where a B125 cover and frame has been approved, this must not be coated in plastic and must have lifting eyes suitable sizes to accommodate standard lifting keys. Screw down covers are not acceptable.
- INWL is not obliged to accept filter drain/land drainage runoff into the public sewer network or adoptable drainage system (directly or indirectly). An alternative method of disposal of the land drainage runoff will therefore be required and you will have to liaise with the Land Drainage Authority/Land Drainage Section with regard to the disposal of the filter drain/land drainage runoff is required.
- Sulphate resisting cement (C20-DX2) and precast concrete products must be used or a laboratory report provided proving that such precautions are not necessary.
- Strength of vitrified clay pipes (if used) to be 40KN/m for 1000, 40KN/m for 1500, 45KN/m for 2250 and 72KN/m for 3000. All concrete pipes to be Class 120 concrete to EN 1916/BS 5911-1:2002.
- All levels of existing drainage to be confirmed prior to work commencing on site.
- The contractor must allow for any fee's required for road and sewer opening permits, sewer connections and make the appropriate applications.
- There should be enough clearance to accommodate the bedding for both pipes, approx 300mm; if crossover is near rocker then the clearance needed may be increased.

FLOW CONTROL DATA

MANUFACTURER	HYDRO INTERNATIONAL
TELEPHONE	01275 878371
TYPE	HYDROBRAKE OPTIMUM
FLOW/HEAD	13.2 l/s @ 3.150m
HYDRO REF	SHE-0135-1320-3150-1320

To be installed in accordance with manufacturers specifications and recommendations before the manhole cover slab is installed



F	MI	18.11.25	Minor revisions to cover & invert levels	MI
E	MI	10.10.25	Amended to client comments and general updates	MI
D	MI	29.08.25	Amended to suit revised road levels	MI
C	MI	29.08.25	Amended to suit planning layout Rev 008L	MI
B	MI	30.04.25	Amended to INWL comments and general updates	MI
A	DJG	04.04.25	Revised to suit new layout	MI
/	JC	26.02.25	Issued for approval	MI
Rev	By	Date	Revision	Chk

ARP ASSOCIATES
 Chartered Consulting Engineers

Northwest House • 5 & 6 Northwest Business Park • Sevia Hill, Leeds • LS6 2QH
 0113 245 9498 • 0113 244 3864 • leeds@arpassociates.co.uk • www.arpassociates.co.uk

ARP Associates is a trading division of ARP Geotechnical Ltd, a company registered in England and Wales with company number 3773815, whose registered office is at 5/6 Northwest Business Park, Sevia Hill, Leeds LS6 2QH

TITLE
**SECTION 104 LAYOUT
 SHEET 4 OF 4**

PROJECT
**BLACKMOORFOOT ROAD,
 HUDDERSFIELD**

CLIENT
**MILLER HOMES
 YORKSHIRE**

DRAWING STATUS
PRELIMINARY

Scale	Date	Drawn
1:500 @ A1	FEB 25	DJG
	Chk.	MI

Dwg. No. **0425/92/03.04** Rev **F**