

Sent: 18 May 2026 17:48

Subject: RE: Attached letter from Kirklees Council regarding application number 2025/93435 at location Land off, Blackmoorfoot Road and Felks Stile Road, Crosland Moor, Huddersfield, HD4 7AD

Hi Nick

Further to the DOC application submitted in connection with the above, I would like to advise the following:

Condition 16 (retaining walls) – This condition can not be discharged pending the satisfactory technical approval of proposed modifications to the existing highway retaining wall on Blackmoorfoot Road and the design of new embankments adjacent to the existing highway.

Condition 17 (structures in the highway)- This condition can not be discharged, pending the satisfactory amendment to the current proposals which entail the construction of unnecessary large drainage structures in the highway in breach of CDM Regulations 2015, as advised in my e-mail 5th May 2026 (copy attached).

Regards

Farhad Khatibi

Bridges & Structures Manager
Structures Section
Highways and Streetscene
Kirklees Council

Highways and Streetscene | Highways Structures | Civic Centre 1 | High Street | Huddersfield | HD1 2NF

☎ **External:** 01484 221000 **Internal:** 74199

Mobile: None

✉ **Email:** farhad.khatibi@kirklees.gov.uk

