

Sent: 06 March 2026 14:02

Subject: RE: Attached letter from Kirklees Council regarding application number 2025/93449 at location Land east of, Abbey Road North, Shepley, Huddersfield, HD8 8FG

I would like to advise that condition 29 (boundary treatments) can not be discharged, as the design of proposed boundary retaining walls and the modification to the existing highway burr wall supporting A629 Abbey Road is liable to a formal technical approval via submission of AIPs.

Regards

Farhad Khatibi

Bridges & Structures Manager
Structures Section
Highways and Streetscene
Kirklees Council

Highways and Streetscene | Highways Structures | Civic Centre 1 | High Street | Huddersfield | HD1 2NF

☎ **External:** 01484 221000 **Internal:** 74199

Mobile: None

✉ **Email:** farhad.khatibi@kirklees.gov.uk

